

RMO SC COMPARISON COOMET.M.H-S3

Final Report

Created by:

V. Skliarov, J. Dovshenko, NSC "Institute of Metrology", Kharkiv, Ukraine
F. Menelao, Physikalisch-Technische Bundesanstalt, Germany
J. Borovský, Czech metrology institute, Czech Republic,
N. Kamkova, E. Obozny, BelGIM, Republic of Belarus
M. Zhamanbalin, KazInSt, Kazakhstan

Abstract:

This report describes the results of comparison COOMET.M.H-S3. The comparison measurements between the five participants NSC "IM" (pilot laboratory), PTB, CMI, BelGIM, KazInSt were started in December 2014 and ended in December 2016.

In the RMO SC, one set of hardness reference blocks were used consisting of 6 (six) blocks of the Superficial-Rockwell scales and hardness levels 90-94 HR15N, 40-50 HR30N, 76-84 HR30N, 43-54 HR45N, 47-53 HR30TW, 70-82 HR30TW. Agreement between results of participants is good.

1. Introduction

The present supplementary comparisons of Superficial-Rockwell hardness scales were organized by the COOMET and registered in BIPM under the cipher COOMET.M.H-S3. This regional comparison was between hardness laboratories of the national metrological institutes of Germany, Ukraine, Belarus, Kazakhstan and Czech Republic.

2. Organization

In December 2014 during TC 1.6 COOMET meeting (Kharkiv, Ukraine) it was decided to entrust the organization of the comparisons on Super-Rockwell hardness scales to the National Scientific Centre “Institute of Metrology” (NSC-IM, Ukraine) as a pilot laboratory. Dr. Vladimir Skliarov (NSC-IM, Ukraine) was appointed the coordinator of the comparisons.

The draft of the technical protocol was agreed upon between the participants of the comparison in 2014. The comparison started in November 2014 and ended in May 2016.

2.1 Participants

The list of participants is given in table 1.

Table 1 – Participants of comparisons

Nº	NMI	Address for sending the sample	Acronym	Contact person
1	National Scientific Centre “Institute of Metrology” (pilot laboratory)	42, Myronosytska str., Kharkiv, 61002, Ukraine	NSC IM	V. Skliarov vladimir.skliarov@gmail.com
2	Physikalisch-Technische Bundesanstalt	100, Bundesallee, Braunschweig, 38116, Germany	PTB	F. Menelao febo.menelao@ptb.de
3	Czech metrology institute	4, V Botanice 15072 Praha 5 Czech Republic	CMI	J. Borovský jborovsky@cmi.cz
4	Belarusian State Institute of Metrology	93, Starovilensky trakt, Minsk, 220053, Belarus	BelGIM	N. Kamkova kamkova@belgim.by E. Obozny obozny@belgim.by
5	Kazakhstan institute of standardization and certification	22/2, Angerskaja str., Karaganda, 100009, Kazakhstan,	KazInSt	M. Zhamanbalin m.zhamanbalin@ksm.kz

2.2 Time schedule

Table 2 shows the scheduled measuring time.

Table 2 -Time schedule

Institute/Country	Date of measurements
NSC-IM, Ukraine	November 2014
PTB, Germany	January 2015
CMI, Czech Republic	May 2015
BelGIM, Belarus	June 2015
KazInSt, Kazakhstan	December 2015
NSC-IM, Ukraine	May 2016

3 Transfer standards

3.1 Description

In the RMO SC, one set of hardness reference blocks were used consisting of 6 (six) blocks of the Superficial-Rockwell scales and hardness levels 90-94 HR15N, 40-50 HR30N, 76-84 HR30N, 43-54 HR45N, 47-53 HR30TW, 70-82 HR30TW. (fig. 1).



Figure 1 Set of Superficial-Rockwell hardness reference blocks

Hardness blocks are manufactured by “Centre “MET” Ltd (Russia) and have a length of 60 mm, width of 40 mm and a thickness of 10 mm (fig. 2).

The upper surface of the block, which is the measurement surface, is finished. The measurement area is defined to be within an engraved grid. A grid (5.5 mm x 5.5 mm) is engraved on the block surface in order to define the coordinates of the test locations. The sizes of the test area and grid allow 49 possible test locations. (fig. 3).



Figure 2 Hardness reference blocks used for the HRTW with the logo of the manufacturer



Figure 3 Layout of the grid on the measurement surface of the hardness reference blocks

3.2 Transportation and Handling

The pilot laboratory was responsible for purchasing the blocks for the regional comparison, while each participating institute assumed the costs for transport, customs and related administrative fees.

The pilot laboratory made measurements at the beginning and at the end of the RMO SC in order to evaluate the stability of the hardness reference blocks used in the RMO SC.

It was recommended for each institute to clean the blocks after unpacking with alcohol and then mark all fields reserved for the institute with a fibre pen on the left top corner. After the measurement all dots on the blocks were to be removed before packing in order to avoid corrosion.

4. Measurand

The measurements were carried out following the Superficial-Rockwell scale definition developed for adoption by National Metrology Institutes (NMIs). Before conducting the

measurements, each participant was required to carry out the calibration of the primary hardness machine.

Each participant made 5 (five) measurement indentations on each hardness reference block. Each indentation was to be made at the center of the open square within the engraved grid lines such that the indentation does not contact an engraved line. The 5 (five) indentations were used to evaluate the stochastic deviations occurring during the measurements, including the evaluation of the inhomogeneity of the hardness distribution across the test surface of the hardness reference blocks.

In addition to the 5 (five) measurement locations, two additional test locations were allocated to each institute to be used for a test measurement or in case a measurement error occurs and the measurement must be repeated. The additional two test locations were indicated as "repeat measurements". For result each participant show only 5 (five) correct measurements exclude test and/or error indentations.

Due to the number of fields on the hardness block surface (35) and the number of indentations to be carried out by each laboratory (5 plus two), the maximum number of participants for each regional comparison is 5 ($35/5=5+2$ for possible errors or test indentation). The Pilot laboratory performed the measurements twice but for correct results show only measurements at the end of comparisons.

5 Methods of measurement

Short descriptions with pictures of the Superficial-Rockwell Primary Hardness Standard Machines (PHSM) used for the measurements by the participants are described in Appendix A.

6 Stability of the standards

In order to evaluate the stability of the standards the pilot laboratory carried out measurements at the beginning and at the end of the comparison. The results are summarised in table 3.

Table 3 - Measurement results at the beginning and at the end of the comparison by the pilot laboratory

Measurand, HR	Result at the begin (1), HR	Result at the end (2), HR	Diff. Δ_{2-1} , HR	Meas. Unc. U, HR	$ \Delta_{2-1} /U$, HR
90 – 94 HR15N	90,92	91,53	-0,24	0,35	0,68
40 – 50 HR30N	47,44	47,82	0,38	0,42	0,9
76 – 84 HR30N	81,2	80,89	-0,31	0,33	0,93
43 – 54 HR45N	51,81	51,62	-0,19	0,32	0,59
47 – 53 HR30TW	53,11	52,99	-0,12	0,47	0,25
70 – 82 HR30TW	78,43	78,73	0,30	0,55	0,54

In the last row the difference between the first and the second measurement Δ_{2-1} is compared to the measurement uncertainty. If the difference is $|\Delta_{2-1}|/U > 1$, it means that the difference Δ_{2-1} cannot be explained by the uncertainty but can be traced back to any change of the hardness reference blocks during the period of the comparison. Since $|\Delta_{2-1}|/U < 1$ for each of the reference blocks, the drift of the test blocks did not significantly influence the uncertainty of measurement results and can be omitted while processing the comparison results.

Therefore, one can conclude that the used hardness reference blocks remained stable.

7 Measurement results

In the following table 4 the results for the hardness reference blocks with hardness levels of 90-94 HR15N, 40-50 HR30N, 76-84 HR30N, 43-54 HR45N, 47-53 HR30TW, 70-82 HR30TW. are summarised. The results are expressed by mean values, the standard deviations S_5 of each set of 5 repetition measurements and the standard deviations between the institutes S_{Inst} .

Table 4 - Results of the measurements for the hardness reference blocks with hardness level 90-94 HR15N, 40-50 HR30N, 76-84 HR30N, 43-54 HR45N, 47 – 53 HR30TW, 70-82 HR30TW.

Institute	90 – 94 HR15N		40 – 50 HR30N		76 – 84 HR30N		43 – 54 HR45N		47 – 53 HR30TW		70 – 82 HR30TW	
	Mean value	Std. dev	Mean value	Std. dev	Mean value	Std. dev						
NSC IM	91,53	0,13	47,82	0,13	80,89	0,15	51,62	0,19	52,99	0,15	78,73	0,21
PTB	91,41	0,19	48,34	0,18	80,71	0,07	51,44	0,25	53,15	0,4	79,04	0,09
CMI	91,24	0,14	47,49	0,12	80,24	0,10	51,04	0,07	52,85	0,18	78,39	0,14
BelGIM	91,23	0,23	47,98	0,35	80,19	0,05	50,68	0,22	52,36	0,25	78,2	0,09
KazInSt	91,54	0,18	47,68	0,14	80,43	0,24	51,12	0,11	52,33	0,42	79,05	0,24
Mean value	91,19		47,72		80,49		50,98		52,54		78,68	
Std.dev, S_i	0,55		0,40		0,84		0,64		0,73		0,38	

8 Uncertainty budgets

8.1 Calculation scheme

The calculation of uncertainty for all the participants was carried out according to [1-4]. The calculation scheme can be seen from the example in table 5 and table 6.

Table 5 - Calculation scheme for HRN scales for the unified estimation of the measurement uncertainty

Quantity, X_i	Symbol, Unit	Estimated value, Δx_i	Standard uncertantiy, $u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$	Sensitivity coefficient, $c_i = \frac{\Delta H}{\Delta x_i}$	Single hardness deviation, $\Delta H_i = \Delta x_i \cdot c_i$, HR	Uncertainty contribution, $u_i(H) = c_i \cdot u(x_i)$ HR	$u_i^4(H) / v_i$
Preliminary test force	F_0 , N	0,2	0,115	0,16	0,032	0,031	1,04988 E-07
Total test force	F , N	1,5	0,866	-0,08	-0,12	-0,121	2,40128 E-05
Indenter cone angle	α_m , °	0,1	0,058	0,13	0,013	0,008	3,52646 E-10
Indenter radius	R_α , μm	1,0	0,577	0,13	0,13	0,075	3,52646 E-06
Indentation depth	l , μm	0,1	0,058	0,5	0,05	0,029	7,71695 E-08
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,021	-0,0147	-0,008	5,76548 E-10
Preliminary test force duration time	T_p , c	0,2	0,115	0,04	0,008	0,005	5,05738 E-11

Total test force duration time	T_{df} , s	0,2	0,115	0,04	0,008	0,005	5,05738 E-11
Deformation of frame	d , μm	0,3	0,173	0,5	0,15	0,087	6,25073 E-06
Total				0,256	0,109		
Combined standard uncertainty, $u(H) = \sqrt{\sum_i u_i^2(H)}$, HRN					0,173		
Coverage factor k for confidence level $p=0,95$					2		
Expanded uncertainty $U = k \cdot u(H)$, HRN					0,345		

Table 6 - Calculation scheme for HRTW scale for the unified estimation of the measurement uncertainty

Quantity, X_i	Symbol, Unit	Estimated value, Δx_i	Standard uncertainty, $u(x)_i = \frac{\Delta x_i}{\sqrt{3}}$	Sensitivity coefficient, $c_i = \frac{\Delta H}{\Delta x_i}$	Single hardness deviation, $\Delta H_i = \Delta x_i \cdot c_i$, HRBW	Uncertainty contribution, $u_i(H) = c_i \cdot u(x_i)$, HRBW	$u_i^4(H) / v_i$
Preliminary test force	F_0 , N	0,2	0,115	0,31	0,062	0,036	1,82445 E-07
Total test force	F , N	1,5	0,866	0,15	0,225	0,130	3,16443 E-05
Indenter ball diameter	R_β , μm	1,0	0,577	0,15	0,15	0,087	6,25073 E-06
Indentation depth	l , μm	0,1	0,058	0,5	0,05	0,029	7,71695 E-08
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,2	-0,14	-0,081	4,74327 E-06
Preliminary test force duration time	T_p , s	0,2	0,115	0,1	0,02	0,012	1,97554 E-09
Total test force duration time	T_{df} , s	0,2	0,115	0,1	0,02	0,012	1,97554 E-09
Deformation of frame	d , μm	0,3	0,173	0,5	0,15	0,087	6,25073 E-06
Total				0,537	0,310		
Combined standard uncertainty, $u(H) = \sqrt{\sum_i u_i^2(H)}$, HRTW					0,202		
Coverage factor k for confidence level $p=0,95$					2		
Expanded uncertainty $U = k \times u(H)$, HRTW					0,404		

From the influencing quantities X_i , measurement deviations ΔX_i and uncertainties in the form of standard deviation S_i (type A) and A_i (type B) are considered.

Sensitivity coefficients:

$c_i = \frac{\Delta H}{\Delta x_i}$	Quantity, X_i	Symbol, Unit
$\frac{\Delta HR}{\Delta F_0}$	Preliminary test force	F_0, N
$\frac{\Delta HR}{\Delta F}$	Total test force	F, N
$\frac{\Delta HR}{\Delta \alpha}$	Indenter cone angle	$\alpha, {}^\circ$
$c_i = \frac{\Delta H}{\Delta x_i}$	Quantity, X_i	Symbol, Unit
$\frac{\Delta HR}{\Delta R_\alpha}$	Indenter radius	$R_\alpha, \mu m$
$\frac{\Delta HR}{\Delta R_\beta}$	Indenter ball diametr	$R_\beta \mu m$
$\frac{\Delta HR}{\Delta l}$	Indentation depth	$l, \mu m$
$\frac{\Delta HR}{\Delta V_{fis}}$	Indentation velocity	$V_{fis}, \mu m \cdot s^{-1}$
$\frac{\Delta HR}{\Delta T_p}$	Preliminary test force duration time	T_p, s
$\frac{\Delta HR}{\Delta T_{df}}$	Total test force duration time	T_{df}, s

Single hardness deviation:

$$\Delta H_i = c_i \cdot \Delta x_i, \quad (1)$$

where Δx_i - estimated value

Variances:

$$u^2(y_i) = c_i^2 u^2(x_i) \quad (2)$$

Combined standard uncertainty:

$$u(H) = \sqrt{\sum_{i=1}^n u^2(y_i)} \quad (3)$$

Sum of hardness deviations:

$$\Delta H = \sum_{i=1}^n \Delta H_i \quad (4)$$

Effective degrees of freedom, according to the Welch-Satterthwaite formula:

$$v_{eff} = \frac{u^4(y)}{\sum_{i=1}^v \frac{u_i^4(y)}{v_i}} \quad (5)$$

Coverage factor:

$$k = f(v_{eff}, P) \quad (6)$$

Expanded standard uncertainty:

$$U(H) = k \cdot u(H) \quad (7)$$

According to this unified procedure for the estimation of measurement uncertainty, the following measurement uncertainties for the participants were received.

8.2 Calculation of measurement uncertainty

As a basis for the determination of the measurement uncertainty the draft guideline to the estimation of the uncertainty of the Superficial-Rockwell measuring method was recommended [1-6].

The uncertainty budgets of the participants based on a unified procedure as presented in clause 8.1 appear in Appendix B. Table 7 shows mean values of hardness measurements and expanded uncertainties of the measurement results for hardness level 90-94 HR15N, 40-50 HR30N, 76-84 HR30N, 43-54 HR45N, 47 – 53 HR30TW, 70-82 HR30TW.

Table 7 – Mean hardness values and expanded uncertainties.

Institutes	90 -94 HR15N		40 -50 HR30N		76 -84 HR30N		43 -54 HR45N		47 – 53 HR30TW		70 - 82 HR30TW	
	Mean value	Exp. uncert.	Mean value	Exp. uncert.	Mean value	Exp. uncert.						
NSC IM	91,53	0,71	47,82	0,76	80,89	0,65	51,62	0,69	52,99	0,66	78,73	0,71
PTB	91,41	0,45	48,34	0,44	80,71	0,41	51,44	0,48	53,15	0,83	79,04	0,80
CMI	91,24	0,53	47,49	0,54	80,24	0,58	51,04	0,45	52,85	0,65	78,39	0,66
BelGIM	91,23	0,53	47,98	0,60	80,19	0,44	50,68	0,55	52,36	0,83	78,20	0,63
KazInSt	91,54	0,70	47,68	0,70	80,43	0,70	51,12	0,70	52,33	1,20	79,05	1,20

9. Analyzing Method of Comparison Results

The measurement results are used to compute the degree of equivalence in Comparison Reference Value (CRV) and E_n ratio. The calculation is shown in following formulas:

- a) calculation of CRV, the Pilot laboratory determined CRV by calculating the weighted mean of measurements of all participants (x_{ref}):

$$x_{ref} = \frac{x_1/u^2(x_1) + x_2/u^2(x_2) + \dots + x_n/u^2(x_n)}{1/u^2(x_1) + 1/u^2(x_2) + \dots + 1/u^2(x_n)}; \quad (8)$$

- b) the uncertainty of the CRV was calculated by following expression:

$$\frac{1}{u^2(x_{ref})} = \frac{1}{u^2(x_1)} + \frac{1}{u^2(x_2)} + \dots + \frac{1}{u^2(x_n)}, \quad (9)$$

where x_i - the measured value of participating institute i ($i = 1, 2, \dots, n$);

$u(x_i)$ - the standard uncertainty of x_i .

Table 8 – Mean hardness values and expanded uncertainties with x_{ref}

Institutes	90 -94 HR15N		40 -50 HR30N		76 -84 HR30N		43 -54 HR45N		47- 53 HR30TW		70 - 82 HR30TW	
	Mean value	Exp. uncert.	Mean value	Exp. uncert.	Mean value	Exp. uncert.						
NSC IM	91,53	0,71	47,82	0,76	80,89	0,65	51,62	0,69	52,99	0,66	78,73	0,71
PTB	91,41	0,45	48,34	0,44	80,71	0,41	51,44	0,48	53,15	0,83	79,04	0,80
CMI	91,24	0,53	47,49	0,54	80,24	0,58	51,04	0,45	52,85	0,65	78,39	0,66
BelGIM	91,23	0,53	47,98	0,60	80,19	0,44	50,68	0,55	52,36	0,83	78,20	0,63
KazInSt	91,54	0,70	47,68	0,70	80,43	0,70	51,12	0,70	52,33	1,20	79,05	1,20
x_{ref}	91,36		47,93		80,48		51,16		52,81		78,57	
$\frac{1}{u^2(x_{ref})}$	16,15		15,12		18,50		16,66		8,27		9,06	
$u^2(x_{ref})$	0,06		0,07		0,05		0,06		0,12		0,11	
$u(x_{ref})$	0,25		0,26		0,23		0,24		0,35		0,33	

In Figures 4-8 reference values x_{ref} are shown by a red line, the dashed blue line shows the expanded uncertainty of the reference value x_{ref} . Expanded uncertainties are shown by black vertical bars. The total length of black vertical bars equals 2U.

Figure 4 shows mean values and expanded uncertainties of hardness measurement results by national laboratories for level 90 -94 HR15N.






Figure 4 Comparisons results for hardness level 90-94 HR15N






Figure 7 Comparisons results for hardness level 43–54 HR45N




Figure 8 Comparisons results for hardness level 47–53 HR30TW




Figure 9 Comparisons results for hardness level 70–82 HR30TW

The results shown in Figure 4 to 9 indicate that the measurement results obtained by the majority of the comparisons participants correlate well with mean hardness values.

c) The deviation from CRV:

$$d_i = x_i - x_{ref} \quad (10)$$

d) The uncertainty of this deviation at a 95% level of confidence:

$$U(d_i) = k \cdot u(d_i) \quad , \quad (11)$$

where $u(d_i)$ was given by ($k = 2$)

$$u(d_i) = \sqrt{u^2(x_i) + u^2(x_{ref})} \quad (12)$$

e) Evaluation of Coefficient E_n :

the equivalence between the measurements of participating institutes was expressed by coefficient E_n as well:

$$E_n = \left| \frac{x_i - x_{ref}}{\sqrt{U^2(x_i) + U^2(x_{ref})}} \right| \quad , \quad (13)$$

where

$$\begin{aligned} U(x_i) &= k \cdot u(x_i), \\ U(x_{ref}) &= k \cdot u(x_{ref}) \end{aligned} \quad . \quad (15)$$

The x_i is considered equivalent with the CRV x_{ref} at 95% confidence level, if $|E_n| \leq 1$.

Table 9 show the intermediate result for next Table 10 and evaluation the deviations.

Table 9 – The intermediate results for further evaluations

		90 -94 HR15N	40 -50 HR30N	76 -84 HR30N	43 -54 HR45N	47-53 HR30TW	70 - 82 HR30TW
NMIs	$U(x_{ref}) = k \cdot u(x_{ref})$	0,50	0,51	0,46	0,49	0,70	0,66
	$U^2(x_{ref})$	0,25	0,26	0,22	0,24	0,48	0,44
NSC IM	$U(x_1) = k \cdot u(x_1)$	0,71	0,76	0,65	0,69	0,66	0,71
	$U^2(x_1)$	0,50	0,58	0,42	0,48	0,44	0,50
PTB	$U(x_2) = k \cdot u(x_2)$	0,45	0,44	0,41	0,48	0,83	0,80
	$U^2(x_2)$	0,20	0,19	0,17	0,23	0,69	0,64
CMI	$U(x_3) = k \cdot u(x_3)$	0,53	0,54	0,58	0,45	0,65	0,66
	$U^2(x_3)$	0,28	0,29	0,34	0,21	0,42	0,43
BelGIM	$U(x_4) = k \cdot u(x_4)$	0,53	0,60	0,44	0,55	0,83	0,63
	$U^2(x_4)$	0,28	0,36	0,19	0,30	0,69	0,40
KazInSt	$U(x_5) = k \cdot u(x_5)$	0,70	0,70	0,70	0,70	1,20	1,20
	$U^2(x_5)$	0,49	0,49	0,49	0,49	1,44	1,44

10. Comparison Results

The comparison results, comparison reference value (CRV), the deviation value of each NMIs from CRV as well as their uncertainty and E_n ratio, are calculated and shown in Table 11, Figure 9, Figure 10, Figure 11, Figure 12, Figure 13 and Figure 14 for Super-Rockwell scale with hardness level 90-94 HR15N, 40-50 HR30N, 76-84 HR30N, 43-54 HR45N, 47 – 53 HR30TW, 70-82 HR30TW.

Table 10 – Comparison results for evaluation

NMIs	Nominal	90 -94 HR15N	40 -50 HR30N	76 -84 HR30N	43 -54 HR45N	47-53 HR30TW	70 - 82 HR30TW
	CRV x_{ref}	91,36	47,93	80,48	51,16	52,81	78,57
	$u^2(x_{ref})$	0,06	0,07	0,05	0,06	0,12	0,11
NSC IM	<i>deviation from CRV</i> $d_i = x_i - x_{ref}$	0,17	-0,11	0,41	0,46	0,18	0,16
	$U(d_i) = k \cdot u(d_i)$	0,71	0,76	0,65	0,69	0,66	0,71
	<i>Evaluation of Coefficient E_n</i>	0,19	-0,12	0,51	0,55	0,19	0,16
PTB	<i>deviation from CRV</i> $d_i = x_i - x_{ref}$	0,05	0,41	0,23	0,28	0,34	0,47
	$U(d_i) = k \cdot u(d_i)$	0,45	0,44	0,41	0,48	0,83	0,80
	<i>Evaluation of Coefficient E_n</i>	0,07	0,60	0,37	0,41	0,31	0,45
CMI	<i>deviation from CRV</i> $d_i = x_i - x_{ref}$	-0,12	-0,44	-0,24	-0,12	0,04	-0,18
	$U(d_i) = k \cdot u(d_i)$	0,53	0,54	0,58	0,45	0,65	0,66
	<i>Evaluation of Coefficient E_n</i>	-0,17	-0,59	-0,32	-0,17	0,04	-0,20
BelGIM	<i>deviation from CRV</i> $d_i = x_i - x_{ref}$	-0,13	0,05	-0,29	-0,48	-0,45	-0,37
	$U(d_i) = k \cdot u(d_i)$	0,53	0,60	0,44	0,55	0,83	0,63
	<i>Evaluation of Coefficient E_n</i>	-0,18	0,06	-0,45	-0,65	-0,42	-0,41
KazInSt	<i>deviation from CRV</i> $d_i = x_i - x_{ref}$	0,18	-0,25	-0,05	-0,04	-0,48	0,48
	$U(d_i) = k \cdot u(d_i)$	0,70	0,70	0,70	0,70	1,20	1,20
	<i>Evaluation of Coefficient E_n</i>	0,21	-0,29	-0,06	-0,04	-0,35	0,35




Figure 9 Deviation from reference value of 90-94 HR15N measurement comparison




Figure 10 Deviation from reference value of 40-50 HR30N measurement comparison




Figure 11 Deviation from reference value of 76-84 HR30N measurement comparison




Figure 12 Deviation from reference value of 43-54 HR45N measurement comparison




Figure 13 Deviation from reference value of 47-53 HRTW30 measurement comparison




Figure 14 Deviation from reference value of 70-82 HR30TW measurement comparison




Figure 14 $|E_n|$ ratio of hardness level 90-94 HR15N, 40-50 HR30N, 76-84 HR30N, 43-54 HR45N, 47 – 53 HR30TW, 70-82 HR30TW measurement comparison

11. Discussions, conclusions and remarks

The COOMET.M.H-S3 comparison can be considered as a successful metrological exercise. At present, Superficial-Rockwell hardness reference blocks with high time-dependent stability and high local homogeneity, including high surface quality are available.

The contribution of this comparison would be quite important because other COOMET countries need the confirmation of traceability by a key comparison.

12. References

- 1 EURAMET/cg-16/v.01, "EA Guidelines on the Estimation of Uncertainty in Hardness Measurements", Previously EA-10/16, July 2007 (<http://www.euramet.org/index.php?id=calibration-guides>).
- 2 R. Samuel, Low: Rockwell Hardness Measurement of Metallic Materials, NIST Recommended Practice Guide, Special Publication 960-5, 2001.
- 3 G. Barbato, S. Desogus, A. Germak, "Hardness measurement from empiricism to metrology an application to Rockwell C scale". -In: "Basic metrology and applications", Ed. Levrotto& Bella, 1994, pp. 112-117.
- 4 L. Brice, F. Davis, A. Crawshaw, "Uncertainty in hardness measurement", NPL Report CMAM 87, April 2003 (<http://www.npl.co.uk/engineering-measurements/mass-force-pressure/hardness/rockwell-hardness-sensitivity-coefficients>).
- 5 W. Bich, M.G. Cox, W.T. Estler, L. Nielsen, W. Woeger: Proposed guidelines for the evaluation of key comparison data, BIPM (2003).
- 6 J.-F. Song, S. Low, D. Pitchure, A. Germak, S. Desogus, T. Polzin, H.-Q. Yang, H.Ishida and G. Barbato, "Establishing a world-wide unified Rockwell hardness scale with metrological traceability", Metrologia34 (1997) 331-342.

AppendixA

Description of the Primary Hardness Standard Machine (PHSM)

NSC “Institute of Metrology”

Name	National primary standards according to Superficial-Rockwell, hardness scales		
Manufacturer	NSC “Institute of Metrology”		
Model	DETU 02-04-99		
S/n	DETU 02-04-99		
Year of construction (and following significant upgrades)	1999		
Hardness Scales	Superficial-Rockwell scales		
	scale	measured	uncertainty
HR, $U_{95\%}$	90 -94 HR15N	91,53 HR15N	0,71 HR15N
	40 -50 HR30N	47,82 HR30N	0,76 HR30N
	76 -84 HR30N	80,89 HR30N	0,65 HR30N
	43 -54 HR45N	51,62 HR45N	0,69 HR45N
	47 – 53 HR30TW	52,99 HR30TW	0,66 HR30TW
	70 - 82 HR30TW	78,73 HR30TW	0,71 HR30TW
Force generation system and $U_{95\%}$	Dead weight, 0,28 N		
Depth measuring system and $U_{95\%}$	0,058 μm		
Indenter (manufacturer, model, s/n)	“Instrument Service” (Ukraine), model NC, s/n 2111		
Picture			

Czech metrology institute

Primary Hardness Standard Machine (PHSM) CMI

Name	National primary standards according to Rockwell hardness			
Manufacturer	PGH –Kraftmessgeräte, Germany			
Model	RNGT 150			
S/n	007/1962			
Year of construction (and following significant upgrades)	1962, the last general overhaul and reconstruction in 2003, replacing the measuring system in 2014			
Year of construction (and following significant upgrades)	Rockwell scales			
HR, $U_{95\%}$ (with own indenter, as results from Annex C)	scale	measured	uncertainty	inhomogeneity
	92 HR15N	90,24 HR15N	0,51 HR15N	0,49 HR15N
	45 HR30N	47,49 HR30N	0,53 HR30N	0,69 HR30N
	80 HR30N	80,24 HR30N	0,57 HR30N	0,38 HR30N
	49HR45N	50,04 HR45N	0,42 HR45N	0,48 HR45N
	50 HR30TW	52,85 HR30TW	0,56 HR30TW	0,80 HR30TW
	76 HR30TW	78,39 HR30TW	0,57 HR30TW	0,63 HR30TW
Force generation system and $U_{95\%}$	Dead weight, 0,20 N			
Depth measuring system and $U_{95\%}$	0,20µm			
Indenter (manufacturer, model, s/n)	Manufacturer Zeiss, s/n 5417			
Pictures (two maximum)	 			

Kazakhstan institute of standardization and certification

Name	National primary standards according to Rockwell and Superficial Rockwell hardness scales		
Manufacturer	Indentec Hardness Testing Machines Ltd, United Kingdom		
Model	8150TK		
S/n	032808		
Year of construction (and following significant upgrades)	2003		
Hardness Scales	Superficial Rockwell N, T scales		
HR, $U_{95\%}$	90 -94 HR15N	91,54 HR15N	0,70 HR15N
	40 -50 HR30N	47,68 HR30N	0,70 HR30N
	76 -84 HR30N	80,43 HR30N	0,70HR30N
	43 -54 HR45N	51,12 HR45N	0,70 HR45N
	47 – 53 HR30TW	52,33 HR30TW	1,20 HR30TW
	70 - 82 HR30TW	79,05 HR30TW	1,20 HR30TW
Force generation system and $U_{95\%}$	Dead weight, 0,28 N		
Depth measuring system and $U_{95\%}$	0,289 μm		
Indenter (manufacturer, model, s/n)	Indentec Hardness Testing Machines Ltd, United Kingdom, s/n 23672		
Picture			

Physikalisch-Technische Bundesanstalt

Name	National primary standards Superficial-Rockwell hardness scales.
Manufacturer	Wazau
Model	RNG3
S/n	
Year of construction (and following significant upgrades)	1969
Hardness Scales	Superficial-Rockwell scales
HR, $U_{95\%}$ (with own indenter, as results from Annex C)	92 ± 2 HR15N = 91,41 HR15N \pm 0,45 HR15N 45 ± 5 HR30N = 48,43 HR30N \pm 0,44 HR30N 80 ± 4 HR30N = 80,71 HR30N \pm 0,41 HR30N 49 ± 6 HR45N = 51,44 HR45N \pm 0,48 HR45N 50 ± 5 HR30TW = 53,15 HR30TW \pm 0,80 HR30TW 76 ± 6 HR30TW = 79,04 HR30TW \pm 0,45 HR30TW
Force generation system and $U_{95\%}$	Dead weight, 0,03 N
Depth measuring system and $U_{95\%}$	0,01 μ m
Indenter (manufacturer, model, s/n)	Stroh, s/n840
Pictures (two maximum)	

Belarusian State Institute of Metrology

Name	Hardness tester
Manufacturer	Indentec
Model	8150SK
S/n	063266
Year of construction (and following significant upgrades)	2006
Hardness Scales	Superficial-Rockwell scales
HR, $U_{95\%}$	$92 \pm 2 \text{ HR15N} = 91,23 \text{ HR15N} \pm 0,53 \text{ HR15N}$ $45 \pm 5 \text{ HR30N} = 47,28 \text{ HR30N} \pm 0,60 \text{ HR30N}$ $80 \pm 4 \text{ HR30N} = 79,19 \text{ HR30N} \pm 0,44 \text{ HR30N}$ $49 \pm 6 \text{ HR45N} = 50,68 \text{ HR45N} \pm 0,55 \text{ HR45N}$ $50 \pm 5 \text{ HR30TW} = 51,46 \text{ HR30TW} \pm 0,83 \text{ HR30TW}$ $76 \pm 6 \text{ HR30TW} = 78,20 \text{ HR30TW} \pm 0,63 \text{ HR30TW}$
Force generation system and $U_{95\%}$	According to the verification scheme in accordance with GOST 8.064-94 for hardness comparator standardized $S\epsilon\Sigma = 0,2$. The accuracy of load and indentation depth measurement system is not monitored.
Depth measuring system and $U_{95\%}$	
Indenter (manufacturer, model, s/n)	Indentec, № 06194
Picture	

Appendix B

Uncertainty budgets of the participants based on a unified procedure

NSC “Institute of Metrology”; hardness level 90-94 HR15N

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRN	$u_i(H)$, HRN	$u_i^4(H) / v_i$
Preliminary test force	F_0 , N	0,2	0,115	0,6	0,12	0,069	2,3E-05
Total test force	F , N	1,5	0,866	-0,06	-0,09	-0,052	7,29E-06
Indenter cone angle	α_m , °	0,1	0,058	0,45	0,045	0,026	4,56E-07
Indenter radius	R_α , μm	1,0	0,577	0,45	0,45	0,260	0,004557
Indentation depth	l , μm	0,1	0,058	1	0,1	0,058	1,11E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,5	-0,35	-0,202	0,001668
Preliminary test force duration time	T_p , s	0,2	0,115	0,1	0,02	0,012	1,78E-08
Total test force duration time	T_{df} , s	0,2	0,115	0,1	0,02	0,012	1,78E-08
Deformation of frame	d , μm	0,3	0,173	0,5	0,15	0,087	5,63E-05
Total					0,465	0,268	
Standard uncertainty						0,357	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,714	

NSC “Institute of Metrology”; hardness level 40-50 HR30N

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRN	$u_i(H)$, HRN	$u_i^4(H) / v_i$
Preliminary test force	F_0 , N	0,2	0,115	0,7	0,14	0,081	4,269E-05
Total test force	F , N	1,5	0,866	-0,2	-0,3	-0,173	0,001
Indenter cone angle	α_m , °	0,1	0,058	-0,41	-0,041	-0,024	3,140E-07
Indenter radius	R_α , μm	1,0	0,577	-0,41	-0,41	-0,237	0,003
Indentation depth	l , μm	0,1	0,058	1	0,1	0,058	1,111E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,5	-0,35	-0,202	0,0017
Preliminary test force duration time	T_p , s	0,2	0,115	0,1	0,02	0,012	1,778E-08
Total test force duration time	T_{df} , s	0,2	0,115	0,1	0,02	0,012	1,778E-08
Deformation of frame	d , μm	0,3	0,173	0,5	0,15	0,087	5,626E-05
Total					-0,671	-0,387	
Standard uncertainty						0,381	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,762	

NSC "Institute of Metrology"; hardness level 76-84 HR30N

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRN	$u_i(H)$, HRN	$u_i^4(H) \bigg/ v_i$
Preliminary test force	F_0 , N	0,2	0,115	0,45	0,09	0,052	7,290E-06
Total test force	F , N	1,5	0,866	0,08	0,12	0,069	2,304E-05
Indenter cone angle	α_m , °	0,1	0,058	0,38	0,038	0,022	2,317E-07
Indenter radius	R_α , μm	1,0	0,577	0,38	0,38	0,219	0,002
Indentation depth	l , μm	0,1	0,058	1	0,1	0,058	1,111E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,5	-0,35	-0,202	0,002
Preliminary test force duration time	T_p , s	0,2	0,115	0,1	0,02	0,012	1,778E-08
Total test force duration time	T_{df} , s	0,2	0,115	0,1	0,02	0,012	1,778E-08
Deformation of frame	d , μm	0,3	0,173	0,5	0,15	0,087	5,626E-05
Total					0,568	0,328	
Standard uncertainty						0,329	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,657	

NSC "Institute of Metrology"; hardness level 43-54 HR45N

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRN	$u_i(H)$, HRN	$u_i^4(H) \bigg/ v_i$
Preliminary test force	F_0 , N	0,2	0,115	0,47	0,094	0,054	8,676E-06
Total test force	F , N	1,5	0,866	-0,25	-0,375	-0,217	0,002
Indenter cone angle	α_m , °	0,1	0,058	0,41	0,041	0,024	3,140E-07
Indenter radius	R_α , μm	1,0	0,577	0,41	0,41	0,237	0,003
Indentation depth	l , μm	0,1	0,058	1	0,1	0,058	1,111E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,08	-0,056	-0,032	1,093E-06
Preliminary test force duration time	T_p , s	0,2	0,115	-0,2	-0,04	-0,023	2,845E-07
Total test force duration time	T_{df} , s	0,2	0,115	-0,2	-0,04	-0,023	2,8445E-07
Deformation of frame	d , μm	0,3	0,173	0,5	0,15	0,087	5,626E-05
Total					0,284	0,164	
Standard uncertainty						0,345	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,691	

NSC “Institute of Metrology”; hardness level 47–53 HR30TW

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRTW	$u_i(H)$, HRTW	$u_i^4(H) \bigg/ v_i$
Preliminary test force	F_0 , N	0,2	0,115	0,1	0,02	0,012	1,78E-08
Total test force	F , N	1,5	0,866	-0,35	-0,525	-0,303	0,008442
Indenter ball diameter	R_β , μm	1,0	0,577	-0,085	-0,085	-0,049	5,8E-06
Indentation depth	l , μm	0,5	0,289	1	0,1	0,058	1,11E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,2	-0,14	-0,081	4,27E-05
Preliminary test force duration time	T_p , s	0,2	0,115	0,1	0,02	0,012	1,78E-08
Total test force duration time	T_{df} , s	0,2	0,115	0,1	0,02	0,012	1,78E-08
Deformation of frame	d , μm	0,3	0,173	0,5	0,15	0,087	5,63E-05
Total					-0,440	-0,254	
Standard uncertainty						0,335	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,669	

NSC “Institute of Metrology”; hardness level 70-82 HR30TW

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRTW	$u_i(H)$, HRTW	$u_i^4(H) \bigg/ v_i$
Preliminary test force	F_0 , N	0,2	0,115	0,085	0,017	0,010	9,28E-09
Total test force	F , N	1,5	0,866	-0,38	-0,57	-0,329	0,01173
Indenter ball diameter	R_β , μm	1,0	0,577	-0,07	-0,07	-0,040	2,67E-06
Indentation depth	l , μm	0,5	0,289	1	0,1	0,058	1,11E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,2	-0,14	-0,081	4,27E-05
Preliminary test force duration time	T_p , s	0,2	0,115	0,1	0,02	0,012	1,78E-08
Total test force duration time	T_{df} , s	0,2	0,115	0,1	0,02	0,012	1,78E-08
Deformation of frame	d , μm	0,3	0,173	0,5	0,15	0,087	5,63E-05
Total					-0,473	-0,273	
Standard uncertainty						0,357	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,715	

Kazakhstan institute of standardization and certification. Uncertainty budget for 90-94 HR15N

Influencing Quantity, X_i	Symbol,Unit	Δx_i	$u(x_i)$	c_i	$u_i(H)$, HRN
Preliminary test force	F_0, N	0,2	0,115	0,670	0,077
Total test force	F, N	1,5	0,866	0,2	0,173
Indenter cone angle	$\alpha_m, {}^\circ$	0,1	0,058	0,350	0,020
Indenter radius	$R_\alpha, \mu m$	1,0	0,577	0,350	0,202
Indentation depth	$l, \mu m$	0,1	0,058	0,9	0,052
Indentation velocity	$V_{fis}, \mu m \cdot s^{-1}$	0,7	0,404	-0,5	-0,202
Preliminary test force duration time	T_p, s	0,2	0,115	0,1	0,012
Total test force duration time	T_{df}, s	0,2	0,115	0,1	0,012
Deformation of frame	$d, \mu m$	0,3	0,173	0,5	0,087
Standard uncertainty					0,359
Coverage factor k for confidence level p=0,95					2
Expanded uncertainty					0,717

Kazakhstan institute of standardization and certification. Uncertainty budget for 40-50 HR30N

Influencing Quantity, X_i	Symbol,Unit	Δx_i	$u(x_i)$	c_i	$u_i(H)$, HRN
Preliminary test force	F_0, N	0,2	0,115	0,670	0,077
Total test force	F, N	1,5	0,866	0,2	0,173
Indenter cone angle	$\alpha_m, {}^\circ$	0,1	0,058	0,350	0,020
Indenter radius	$R_\alpha, \mu m$	1,0	0,577	0,350	0,202
Indentation depth	$l, \mu m$	0,1	0,058	0,9	0,052
Indentation velocity	$V_{fis}, \mu m \cdot s^{-1}$	0,7	0,404	-0,5	-0,202
Preliminary test force duration time	T_p, s	0,2	0,115	0,1	0,012
Total test force duration time	T_{df}, s	0,2	0,115	0,1	0,012
Deformation of frame	$d, \mu m$	0,3	0,173	0,5	0,087
Standard uncertainty					0,359
Coverage factor k for confidence level p=0,95					2
Expanded uncertainty					0,717

Kazakhstan institute of standardization and certification. Uncertainty budget for 76-84 HR30N

Influencing Quantity, X_i	Symbol,Unit	Δx_i	$u(x_i)$	c_i	$u_i(H)$, HRN
Preliminary test force	F_0, N	0,2	0,115	0,670	0,077
Total test force	F, N	1,5	0,866	0,2	0,173
Indenter cone angle	$\alpha_m, {}^\circ$	0,1	0,058	0,350	0,020
Indenter radius	$R_\alpha, \mu m$	1,0	0,577	0,350	0,202
Indentation depth	$l, \mu m$	0,1	0,058	0,9	0,052
Indentation velocity	$V_{fis}, \mu m \cdot s^{-1}$	0,7	0,404	-0,5	-0,202
Preliminary test force duration time	T_p, s	0,2	0,115	0,1	0,012
Total test force duration time	T_{df}, s	0,2	0,115	0,1	0,012
Deformation of frame	$d, \mu m$	0,3	0,173	0,5	0,087
Standard uncertainty					0,359
Coverage factor k for confidence level p=0,95					2
Expanded uncertainty					0,717

Kazakhstan institute of standardization and certification. Uncertainty budget for 43-54 HR45N

Influencing Quantity, X_i	Symbol,Unit	Δx_i	$u(x_i)$	c_i	$u_i(H)$, HRN
Preliminary test force	F_0, N	0,2	0,115	0,670	0,077
Total test force	F, N	1,5	0,866	0,2	0,173
Indenter cone angle	$\alpha_m, {}^\circ$	0,1	0,058	0,350	0,020
Indenter radius	$R_\alpha, \mu m$	1,0	0,577	0,350	0,202
Indentation depth	$l, \mu m$	0,1	0,058	0,9	0,052
Indentation velocity	$V_{fis}, \mu m \cdot s^{-1}$	0,7	0,404	-0,5	-0,202
Preliminary test force duration time	T_p, s	0,2	0,115	0,1	0,012
Total test force duration time	T_{df}, s	0,2	0,115	0,1	0,012
Deformation of frame	$d, \mu m$	0,3	0,173	0,5	0,087
Standard uncertainty					0,359
Coverage factor k for confidence level p=0,95					2
Expanded uncertainty					0,717

Kazakhstan institute of standardization and certification. Uncertainty budget for 47–53 HR30TW

Influencing Quantity, X_i	Symbol,Unit	Δx_i	$u(x_i)$	c_i	$u_i(H)$, HRTW
Preliminary test force	F_0 , N	0,2	0,115	0,1	0,012
Total test force	F , N	1,5	0,866	-0,6	-0,520
Indenter ball diameter	R_β , μm	1,0	0,577	-0,09	-0,052
Indentation depth	l , μm	0,5	0,289	0,9	0,260
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,2	-0,081
Preliminary test force duration time	T_p , s	0,2	0,115	0,08	0,009
Total test force duration time	T_{df} , s	0,2	0,115	0,05	0,006
Deformation of frame	d , μm	0,3	0,173	0,05	0,009
Standard uncertainty					0,589
Coverage factor k for confidence level p=0,95					2
Expanded uncertainty					1,178

Kazakhstan institute of standardization and certification. Uncertainty budget for 70-82 HR30TW

Influencing Quantity, X_i	Symbol,Unit	Δx_i	$u(x_i)$	c_i	$u_i(H)$, HRTW
Preliminary test force	F_0 , N	0,2	0,115	0,1	0,012
Total test force	F , N	1,5	0,866	-0,6	-0,520
Indenter ball diameter	R_β , μm	1,0	0,577	-0,09	-0,052
Indentation depth	l , μm	0,5	0,289	0,9	0,260
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	-0,2	-0,081
Preliminary test force duration time	T_p , s	0,2	0,115	0,08	0,009
Total test force duration time	T_{df} , s	0,2	0,115	0,05	0,006
Deformation of frame	d , μm	0,3	0,173	0,05	0,009
Standard uncertainty					0,589
Coverage factor k for confidence level p=0,95					2
Expanded uncertainty					1,178

Czech metrology institute; hardness level 90-94 HR15N

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRN	$u_i(H)$, HRN	$u_i^4(H) / v_i$
Preliminary test force	F_0 , N	0,2	0,087	0,693	0,104	0,060	1,3E-05
Total test force	F , N	1,2	0,693	0,110	0,132	0,076	3,37E-05
Indenter cone angle	α_m , °	0,1	0,058	0,180	0,018	0,010	1,17E-08
Indenter radius	R_α , μm	1,0	0,577	0,300	0,300	0,173	0,0009
Indentation depth	l , μm	0,1	0,058	1,000	0,100	0,058	1,11E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,7	0,404	0,293	0,205	0,118	0,000197
Preliminary test force duration time	T_p , s	0,2	0,115	-0,905	-0,181	-0,105	0,000119
Total test force duration time	T_{df} , s	0,2	0,115	0,128	0,026	0,015	4,77E-08
Deformation of frame	d , μm	0,2	0,087	0,120	0,048	0,028	5,9E-07
Total					0,752	0,434	
Standard uncertainty						0,262	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,525	

Czech metrology institute; hardness level 40-50 HR30N

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRN	$u_i(H)$, HRN	$u_i^4(H) / v_i$
Preliminary test force	F_0 , N	0,15	0,087	0,534	0,080	0,046	4,574E-06
Total test force	F , N	1,20	0,693	0,241	0,289	0,167	0,0001
Indenter cone angle	α_m , °	0,20	0,115	0,180	0,036	0,021	1,866E-07
Indenter radius	R_α , μm	0,90	0,520	0,300	0,270	0,156	0,001
Indentation depth	l , μm	0,1	0,058	1,000	0,100	0,058	1,11E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,90	0,520	0,144	0,130	0,075	3,135E-05
Preliminary test force duration time	T_p , s	0,20	0,115	0,822	0,164	0,095	8,117E-05
Total test force duration time	T_{df} , s	0,20	0,115	0,060	0,012	0,007	2,304E-09
Deformation of frame	d , μm	0,40	0,231	0,120	0,048	0,028	5,899E-07
Total					1,129	0,652	
Standard uncertainty						0,271	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,542	

Czech metrology institute; hardness level 76-84 HR30N

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRN	$u_i(H)$, HRN	$u_i^4(H) \sqrt{v_i}$
Preliminary test force	F_0 , N	0,15	0,087	0,656	0,098	0,057	1,04181E-05
Total test force	F , N	1,20	0,693	0,291	0,349	0,202	0,001652363
Indenter cone angle	α_m , °	0,20	0,115	0,180	0,036	0,021	1,86646E-07
Indenter radius	R_α , μm	0,90	0,520	0,300	0,270	0,156	0,000590559
Indentation depth	l , μm	0,1	0,058	1,000	0,100	0,058	1,11E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,90	0,520	0,202	0,182	0,105	0,00012139
Preliminary test force duration time	T_p , s	0,20	0,115	-0,001	0,000	0,000	1,77799E-16
Total test force duration time	T_{df} , s	0,20	0,115	-0,034	-0,007	-0,004	2,37599E-10
Deformation of frame	d , μm	0,40	0,231	0,120	0,048	0,028	5,89893E-07
Total					1,076	0,621	
Standard uncertainty						0,289	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,579	

Czech metrology institute; hardness level 43-54 HR45N

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRN	$u_i(H)$, HRN	$u_i^4(H) \sqrt{v_i}$
Preliminary test force	F_0 , N	0,15	0,087	0,171	0,0257	0,015	4,81014E-08
Total test force	F , N	1,20	0,693	0,129	0,1548	0,089	6,38105E-05
Indenter cone angle	α_m , °	0,10	0,058	0,180	0,0180	0,010	1,16654E-08
Indenter radius	R_α , μm	1,00	0,577	0,300	0,3000	0,173	0,000900106
Indentation depth	l , μm	0,15	0,087	1,000	0,1500	0,087	5,62566E-05
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	1,00	0,577	0,118	0,1180	0,068	2,15445E-05
Preliminary test force duration time	T_p , s	0,20	0,115	0,032	0,0064	0,004	1,86435E-10
Total test force duration time	T_{df} , s	0,20	0,115	-0,082	-0,0164	-0,009	8,03866E-09
Deformation of frame	d , μm	0,40	0,231	0,120	0,0480	0,028	5,89893E-07
Total					0,804	0,464	
Standard uncertainty						0,227	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,453	

Czech metrology institute; hardness level 47–53 HR30TW

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRTW	$u_i(H)$, HRTW	$u_i^4(H) \bigg/ v_i$
Preliminary test force	F_0 , N	0,15	0,087	0,161	0,0242	0,014	3,78E-08
Total test force	F , N	1,20	0,693	0,144	0,1728	0,100	9,91E-05
Indenter ball diameter	R_β , μm	2,00	1,155	0,200	0,4000	0,231	0,002845
Indentation depth	l , μm	0,30	0,173	1,000	0,3000	0,173	0,0009
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,90	0,520	0,200	0,1800	0,104	0,000117
Preliminary test force duration time	T_p , s	0,20	0,115	0,100	0,0200	0,012	1,78E-08
Total test force duration time	T_{df} , s	0,20	0,115	-0,017	-0,0034	-0,002	1,48E-11
Deformation of frame	d , μm	0,40	0,231	0,120	0,0480	0,028	5,9E-07
Total					1,142	0,659	
Standard uncertainty						0,324	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,649	

Czech metrology institute; hardness level 70-82 HR30TW

Influencing Quantity, X_i	Symbol, Unit	Δx_i	$u(x_i)$	c_i	ΔH_i , HRTW	$u_i(H)$, HRTW	$u_i^4(H) \bigg/ v_i$
Preliminary test force	F_0 , N	0,15	0,087	0,066	0,010	0,006	1,07E-09
Total test force	F , N	1,20	0,693	0,261	0,313	0,181	0,001069
Indenter ball diameter	R_β , μm	2,00	1,155	-0,160	-0,320	-0,185	0,001165
Indentation depth	l , μm	0,30	0,173	1,000	0,3000	0,173	0,0009
Indentation velocity	V_{fis} , $\mu m \cdot s^{-1}$	0,90	0,520	0,200	0,180	0,104	0,000117
Preliminary test force duration time	T_p , s	0,20	0,115	0,125	0,025	0,014	4,34E-08
Total test force duration time	T_{df} , s	0,20	0,115	-0,017	-0,003	-0,002	1,48E-11
Deformation of frame	d , μm	0,40	0,231	0,120	0,048	0,028	5,9E-07
Total					0,553	0,319	
Standard uncertainty						0,330	
Coverage factor k for confidence level p=0,95						2	
Expanded uncertainty						0,659	

Belarusian State Institute of Metrology

The uncertainty value of the hardness reference blocks has been calculated according to the calibration procedure MRP MK 47 03.29-2013, which was developed by BelGIM on the basis of ISO 6508-3:2005. The use of a custom BelGIM calibration procedure is due to the fact that ISO 6508-3:2005 is currently not implemented in the Republic of Belarus and hence it cannot be applied directly.

Since BelGIM does not possess appropriate equipment to realize hardness units on its own, the calibration was conducted by using both reference hardness blocks calibrated at the VNIIIFTRI and hardness comparators. For the same reason, the calibration procedure specified above was used instead of the one given in the technical report (any direct calibration of our hardness machines makes no sense, because they are being adjusted against the reference hardness blocks).

As the hardness value of the reference block under calibration a median value was taken inclusive of an appropriate correction obtained by using a 1st class reference hardness block.

A rather large expanded uncertainty was resulting from the uncertainty value specified in the calibration certificate for the relevant 1st class hardness block.

National standards for hardness units, which are planned to be established in 2017-2019, will allow avoiding the use of hardness comparators and provide means for our stand-alone realization of hardness units with the smallest uncertainty value.

The measurement results for each hardness block together with their uncertainty calculation are presented below.

No hardness block	Result
7/14 HR15N	91,23 ± 0,53
9/14 HR30N	47,98±0,60
8/14 HR30N	80,19 ± 0,44
10/14 HR45N	50,68± 0,55
12/14 HR30TW	52,36 ± 0,83
11/14 HR30TW	78,20 ± 0,63

Measurements for hardness block № 7/14 HR15N

Measurements on a reference hardness block 1st category

Actual value of the hardness block 1st category, H_d , HRN	90,67	
Results of measurements on hardness block 1st category, H_{1i} , HRN	1	90,1
	2	89,8
	3	90,4
	4	90,1
	5	90,3
arithmetic mean value of hardness, \bar{H} , HRN	90,14	
Standard uncertainty, $u(\bar{H})$, HRN	0,10	
combined standard uncertainty of hardness block 1st category, U , HRN	0,45	
Standard uncertainty of hardness block 1st category, $u(H_d)$, HRN	0,225	
Standard uncertainty, $u(\delta_{ms})$, HRN	0,03	

Measurements on calibrated hardness block

m6 – 89,7 HRN – test measurement

m2 – 89,8 HRN – not used in the calculation

Number of measurements		5				
Measurement results H_i , HRN		m1	m7	m3	m4	m5
		90,6	90,7	90,7	90,8	90,6
Ranging measurements hardness, HRN	1	90,6				
	2	90,6				
	3	90,7				
	4	90,7				
	5	90,8				
Median, H_{mes} , HRN		90,7				
Value $ H_i - H_{mes} $, HRN		0,1	0,1	0	0	0,1
Ranging results $ H_i - H_{mes} $, HRN	1	0				
	2	0				
	3	0,1				
	4	0,1				
	5	0,1				
Median $ H_i - H_{mes} S^*$, HRN		0,1				
Standard deviation, s^* , HRN		0,15				
Standard uncertainty, $u(H_{mes})$, HRN		0,08				
combined standard uncertainty, U , HRN		0,26				
coverage factor		2				
expanded uncertainty, U , HRN		0,53				
Range, HRN		0,2				
Hardness calibrated block, HRN	91,23±0,53					

Measurements for hardness block № 9/14 HR30N

Measurements on a reference hardness block 1st category

Actual value of the hardness block 1st category, H_d , HRN	46,82	
Results of measurements on hardness block 1st category, H_{1i} , HRN	1	45,9
	2	46,1
	3	46,2
	4	45,7
	5	45,8
arithmetic mean value of hardness, \bar{H} , HRN	45,94	
Standard uncertainty, $u(\bar{H})$, HRN	0,09	
combined standard uncertainty of hardness block 1st category, U , HRN	0,46	
Standard uncertainty of hardness block 1st category, $u(H_d)$, HRN	0,23	
Standard uncertainty, $u(\delta_{ms})$, HRN	0,03	

Measurements on calibrated hardness block

m6 – 46,5 HRN – test measurement

m7 – 46,1 HRN – not used in the calculation

Number of measurements		5				
Measurement results H_i , HRN		m1	m2	m3	m4	m5
		46,4	46,3	46,6	46,7	45,8
Ranging measurements hardness, HRN	1	45,8				
	2	46,3				
	3	46,4				
	4	46,6				
	5	46,7				
Median, H_{mes} , HRN		46,4				
Value $ H_i - H_{mes} $, HRN		0,6	0,1	0	0,2	0,3
Ranging results $ H_i - H_{mes} $, HRN	1	0				
	2	0,1				
	3	0,2				
	4	0,3				
	5	0,6				
Median $ H_i - H_{mes} S^*$, HRN		0,2				
Standard deviation, s^* , HRN		0,2966				
Standard uncertainty, $u(H_{mes})$, HRN		0,166				
combined standard uncertainty, U , HRN		0,30				
coverage factor		2				
expanded uncertainty, U , HRN		0,60				
Range, HRN		0,9				
Hardness calibrated block, HRN	47,98 ± 0,60					

Measurements for hardness block № 8/14 HR30N

Measurements on a reference hardness block 1st category

Actual value of the hardness block 1st category, H_d , HRN	78,79	
Results of measurements on hardness block 1st category, H_{1i} , HRN	1	79,7
	2	79,7
	3	79,7
	4	79,7
	5	79,7
arithmetic mean value of hardness, \bar{H} , HRN	79,7	
Standard uncertainty, $u(\bar{H})$, HRN	0,00	
combined standard uncertainty of hardness block 1st category, U , HRN	0,44	
Standard uncertainty of hardness block 1st category, $u(H_d)$, HRN	0,22	
Standard uncertainty, $u(\delta_{ms})$, HRN	0,03	

Measurements on calibrated hardness block

m6 – 80,1 HRN – test measurement

m7 – 80,2 HRN – not used in the calculation

Number of measurements		5				
Measurement results H_i , HRN		m1	m2	m3	m4	m5
		80,0	80,1	80,2	80,1	80,1
Ranging measurements hardness, HRN	1	80,0				
	2	80,0				
	3	80,1				
	4	80,1				
	5	80,2				
Median, H_{mes} , HRN		80,1				
Value $ H_i - H_{mes} $, HRN		0,1	0,1	0	0	0
Ranging results $ H_i - H_{mes} $, HRN	1	0				
	2	0				
	3	0				
	4	0,1				
	5	0,1				
Median $ H_i - H_{mes} S^*$, HRN		0				
Standard deviation, s^* , HRN		0,00				
Standard uncertainty, $u(H_{mes})$, HRN		0,00				
combined standard uncertainty, u , HRN		0,22				
coverage factor		2				
expanded uncertainty, U , HRN		0,44				
Range, HRN		0,1				
Hardness calibrated block, HRN	80,19 ± 0,44					

Measurements for hardness block № 10/14 HR45N

Measurements on a reference hardness block 1st category

Actual value of the hardness block 1st category, H_d , HRN	49,88	
Results of measurements on hardness block 1st category, H_{1i} , HRN	1	49,6
	2	49,7
	3	49,4
	4	49,6
	5	49,7
arithmetic mean value of hardness, \bar{H} , HRN	49,6	
Standard uncertainty, $u(\bar{H})$, HRN	0,05	
combined standard uncertainty of hardness block 1st category, U , HRN	0,51	
Standard uncertainty of hardness block 1st category, $u(H_d)$, HRN	0,26	
Standard uncertainty, $u(\delta_{ms})$, HRN	0,03	

Measurements on calibrated hardness block

m6 – 50,6 HRN – test measurement

m7 – 50,3 HRN – not used in the calculation

Number of measurements		5				
Measurement results H_i , HRN		m1	m2	m3	m4	m5
		50,7	50,5	50,1	50,4	50,4
Ranging measurements hardness, HRN	1			50,1		
	2			50,4		
	3			50,4		
	4			50,5		
	5			50,7		
Median, H_{mes} , HRN				50,4		
Value $ H_i - H_{mes} $, HRN		0,3	0	0	0,1	0,3
Ranging results $ H_i - H_{mes} $, HRN	1			0		
	2			0		
	3			0,1		
	4			0,3		
	5			0,3		
Median $ H_i - H_{mes} S^*$, HRN				0,1		
Standard deviation, s^* , HRN				0,1483		
Standard uncertainty, $u(H_{mes})$, HRN				0,08290222		
combined standard uncertainty, u , HRN				0,28		
coverage factor				2		
expanded uncertainty, U , HRN				0,55		
Range, HRN				0,6		
Hardness calibrated block, HRN	50,68 ± 0,55					

Measurements for hardness block № 12/14 HR30TW

Measurements on a reference hardness block 1st category

Actual value of the hardness block 1st category, H_d , HRTW		58,34
Results of measurements on hardness block 1st category, H_{1i} , HRTW	1	59
	2	58,6
	3	58,7
	4	58,7
	5	58,9
arithmetic mean value of hardness, \bar{H} , HRTW		58,78
Standard uncertainty, $u(\bar{H})$, HRTW		0,073
combined standard uncertainty of hardness block 1st category, U , HRTW		0,8
Standard uncertainty of hardness block 1st category, $u(H_d)$, HRTW		0,4
Standard uncertainty, $u(\delta_{ms})$, HRTW		0,03

Measurements on calibrated hardness block

m6 – 52,2 HRTW – test measurement

m7 – 52,4 HRTW – not used in the calculation

Number of measurements		5				
Measurement results H_i , HRTW		m1	m2	m3	m4	m5
		51,8	51,5	52,2	51,9	51,9
Ranging measurements hardness, HRTW	1		51,5			
	2		51,8			
	3		51,9			
	4		51,9			
	5		52,2			
Median, H_{mes} , HRTW				51,9		
Value $ H_i - H_{mes} $, HRTW		0,4	0,1	0	0	0,3
Ranging results $ H_i - H_{mes} $, HRTW	1		0			
	2		0			
	3		0,1			
	4		0,3			
	5		0,4			
Median $ H_i - H_{mes} S^*$, HRTW				0,1		
standard deviation, s^* , HRTW				0,15		
Standard uncertainty, $u(H_{mes})$, HRTW				0,08		
combined standard uncertainty, u , HRTW				0,42		
coverage factor				2		
expanded uncertainty, U , HRTW				0,83		
Range, HRTW				0,7		
Hardness calibrated block, HRTW				52,36 ± 0,83		

Measurements for hardness block № 11/14 HR30TW

Measurements on a reference hardness block 1st category

Actual value of the hardness block 1st category, H_d , HRTW		78,26
Results of measurements on hardness block 1st category, H_{1i} , HRTW	1	78,6
	2	78,6
	3	78,7
	4	78,6
	5	78,8
arithmetic mean value of hardness, \bar{H} , HRTW		78,66
Standard uncertainty, $u(\bar{H})$, HRTW		0,040
combined standard uncertainty of hardness block 1st category, U , HRTW		0,6
Standard uncertainty of hardness block 1st category, $u(H_d)$, HRTW		0,3
Standard uncertainty, $u(\delta_{ms})$, HRTW		0,03

Measurements on calibrated hardness block

m6 – 78,5 HRTW – test measurement

m7 – 78,4 HRTW – not used in the calculation

Number of measurements		5				
Measurement results H_i , HRTW		m1	m2	m3	m4	m5
	78,6	78,6	78,5	78,7	78,7	
Ranging measurements hardness, HR	1		78,5			
	2		78,6			
	3		78,6			
	4		78,7			
	5		79,7			
Median, H_{mes} , HRTW			78,6			
Value $ H_i - H_{mes} $, HRTW		0,1	0	0	0,1	0,1
Ranging results $ H_i - H_{mes} $, HRTW	1		0			
	2		0			
	3		0,1			
	4		0,1			
	5		0,1			
Median $ H_i - H_{mes} S^*$, HRTW			0,1			
standard deviation, s^* , HRTW			0,15			
Standard uncertainty, $u(H_{mes})$, HRTW			0,08			
combined standard uncertainty, u , HRTW			0,32			
coverage factor			2			
expanded uncertainty, U , HRTW			0,63			
Range, HRTW			0,2			
Hardness calibrated block, HRTW		78,20 ± 0,63				

Physikalisch-Technische Bundesanstalt;

Uncertainty budget for HRN

Quantity	Estimated value		Standard uncertainty	Sensitivity coefficient	Uncertainty contribution
X_i	ΔX_i	$u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$	C_i	$u_i(H)$	
Preliminary test force, F_0	0,01	N	0,0058	0,47	0,0027
Total test force, F	0,03	N	0,0173	-0,25	-0,0043
Permanent depth of measuring device, h	0,01	μm	0,0058	1,00	0,0058
Preliminary test force dwell time, t_0	0,2	s	0,1155	-0,20	-0,0231
Indentation velocity, v	2	$\mu\text{m}/\text{s}$	1,1547	-0,04	-0,0462
Total test force dwell time, t	0,2	s	0,1155	-0,20	-0,0231
Indenter angle, α	0,1	$^\circ$	0,0577	0,41	0,0237
Indenter radius, r	1	μm	0,5774	0,30	0,1732
Combined uncertainty, u_c					0,1839
Expanded uncertainty, Ue					k=2 0,37

Physikalisch-Technische Bundesanstalt;

Uncertainty budget for HRT

Quantity	Estimated value		Standard uncertainty	Sensitivity coefficient	Uncertainty contribution
X_i	ΔX_i	$u(x_i) = \frac{\Delta x_i}{\sqrt{3}}$	C_i	$u_i(H)$	
Preliminary test force, F_0	0,01	N	0,0058	0,50	0,0029
Total test force, F	0,03	N	0,0173	0,30	0,0052
Permanent depth of measuring device, h	0,01	μm	0,0058	0,50	0,0029
Preliminary test force dwell time, t_0	0,2	s	0,1155	0,35	0,0404
Indentation velocity, v	2	$\mu\text{m}/\text{s}$	1,1547	0,32	0,3695
Total test force dwell time, t	0,2	s	0,1155	0,23	0,0266
Indenter diameter, d	0,1	μm	0,0577	0,35	0,0202
Combined uncertainty, u_c					0,3733
Expanded uncertainty, Ue					k=2 0,75