

## Key comparison CCEM.RF-K9

**MEASURAND : Excess noise ratio**

**NOISE SOURCE : TSA1**

**REFERENCE PLANE : R140**

$x_i$  : averaged Excess noise ratio measured by laboratory  $i$

$u_i$  : averaged standard uncertainty of  $x_i$

Lab $i$	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	Date of measurement
	Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz		
LNE	15.700	0.038	15.718	0.038	15.681	0.039	15.683	0.039	15.666	0.039	Sep 97, Jan 99, Dec 00
NPL	15.687	0.021	15.682	0.024	15.689	0.020	15.659	0.031	15.658	0.021	May 98
PTB	15.709	0.013	15.719	0.015	15.700	0.016	15.683	0.018	15.645	0.021	Jun 97, Apr 99
NIST	15.689	0.018	15.683	0.018	15.676	0.019	15.666	0.020	15.655	0.020	Apr 00
VNIIFTRI	15.817	0.031	15.747	0.027	15.717	0.028	15.775	0.026	-	-	Sep - Oct 00

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSA1

REFERENCE PLANE : R140

At each frequency, the key comparison reference value,  $x_R$ , is calculated as the unweighted mean of the participants results with exclusion of outliers. Its standard uncertainty  $u_R$  is computed as given in page 112 of the Final Report.

Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz	
$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB
15.696	0.005	15.710	0.012	15.693	0.007	15.673	0.006	15.656	0.004

The degree of equivalence of laboratory  $i$  with respect to the key comparison reference value is given by a pair of terms terms, both expressed in dB:  $D_i = (x_i - x_R)$  and its expanded uncertainty  $U_i$  ( $k = 2$ ). The equations for the computation of  $U_i$  are given in page 112 of the Final Report.

The degree of equivalence between two laboratories  $i$  and  $j$  is given by a pair of terms, both expressed in dB :

$D_{ij} = (D_i - D_j)$  and its expanded uncertainty  $U_{ij}$  ( $k = 2$ ) with  $U_{ij} = 2(u_i^2 + u_j^2)^{1/2}$ .

Note that the terms  $D_i$  and  $D_{ij}$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSA1

REFERENCE PLANE : R140

FREQUENCY : 12.4 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.004	0.054
NPL	-0.009	0.031
PTB	0.012	0.020
NIST	-0.007	0.027
VNIIFTRI	0.121	0.063

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.013	0.086	-0.009	0.079	0.011	0.083	-0.117	0.098
-0.013	0.086			-0.022	0.049	-0.002	0.055	-0.130	0.075
0.009	0.079	0.022	0.049			0.020	0.044	-0.108	0.067
-0.011	0.083	0.002	0.055	-0.020	0.044			-0.128	0.072
0.117	0.098	0.130	0.075	0.108	0.067	0.128	0.072		

FREQUENCY : 13.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.008	0.063
NPL	-0.028	0.045
PTB	0.009	0.033
NIST	-0.027	0.037
VNIIFTRI	0.037	0.049

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.036	0.089	-0.001	0.081	0.035	0.083	-0.029	0.093
-0.036	0.089			-0.037	0.056	-0.001	0.060	-0.065	0.072
0.001	0.081	0.037	0.056			0.036	0.046	-0.028	0.061
-0.035	0.083	0.001	0.060	-0.036	0.046			-0.064	0.065
0.029	0.093	0.065	0.072	0.028	0.061	0.064	0.065		

FREQUENCY : 15 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	-0.012	0.063
NPL	-0.004	0.034
PTB	0.007	0.029
NIST	-0.017	0.033
VNIIFTRI	0.024	0.046

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		-0.008	0.088	-0.019	0.085	0.005	0.087	-0.036	0.097
0.008	0.088			-0.011	0.051	0.013	0.055	-0.028	0.069
0.019	0.085	0.011	0.051			0.024	0.050	-0.018	0.064
-0.005	0.087	-0.013	0.055	-0.024	0.050			-0.041	0.068
0.036	0.097	0.028	0.069	0.018	0.064	0.041	0.068		

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSA1

REFERENCE PLANE : R140

FREQUENCY : 17.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.010	0.056
NPL	-0.014	0.045
PTB	0.010	0.028
NIST	-0.007	0.031
VNIIFTRI	0.102	0.053

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.024	0.100	0.000	0.086	0.017	0.088	-0.092	0.094
-0.024	0.100			-0.024	0.072	-0.007	0.074	-0.116	0.081
0.000	0.086	0.024	0.072			0.017	0.054	-0.092	0.063
-0.017	0.088	0.007	0.074	-0.017	0.054			-0.109	0.066
0.092	0.094	0.116	0.081	0.092	0.063	0.109	0.066		

FREQUENCY : 18 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.010	0.056
NPL	0.002	0.031
PTB	-0.011	0.030
NIST	-0.001	0.030


LNE		NPL		PTB		NIST	
$D_{ij}$ / dB	$U_{ij}$ / dB						
		0.008	0.089	0.021	0.089	0.011	0.088
-0.008	0.089			0.013	0.059	0.003	0.058
-0.021	0.089	-0.013	0.059			-0.010	0.057
-0.011	0.088	-0.003	0.058	0.010	0.057		

**CCEM.RF-K9**

**Excess noise ratio, 12.4 GHz**

**Source : TSA1, Reference plane : R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 13.5 GHz**


**Source : TSA1, Reference plane : R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$ , ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**      Excess noise ratio, 15 GHz  
Source : TSA1, Reference plane : R140  
Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$ , ( $k = 2$ )




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 17.5 GHz**

**Source : TSA1, Reference plane : R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 18 GHz**

**Source : TSA1, Reference plane : R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

**MEASURAND : Excess noise ratio**

**NOISE SOURCE : TSB1**

**REFERENCE PLANE : PC-7 / R140**

$x_i$  : averaged Excess noise ratio measured by laboratory  $i$

$u_i$  : averaged standard uncertainty of  $x_i$

Lab $i$	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	Date of measurement
	Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz		
LNE	15.785	0.039	15.835	0.039	15.836	0.040	15.692	0.040	15.582	0.039	Sep 97, Jan 99, Dec 00
NPL	15.787	0.021	15.822	0.024	15.857	0.020	15.667	0.031	15.608	0.021	May 98
PTB	15.792	0.014	15.838	0.015	15.835	0.018	15.696	0.019	15.546	0.021	Jun 97, Apr 99
NIST	15.773	0.018	15.801	0.018	15.826	0.018	15.697	0.019	15.575	0.020	Apr 00
VNIIFTRI	15.870	0.036	15.874	0.028	15.848	0.033	15.899	0.026	-	-	Sep - Oct 00

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB1

REFERENCE PLANE : PC-7 / R140

At each frequency, the key comparison reference value,  $x_R$ , is calculated as the unweighted mean of the participants results with exclusion of outliers. Its standard uncertainty  $u_R$  is computed as given in page 112 of the Final Report.

Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz	
$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB
15.784	0.004	15.834	0.012	15.840	0.005	15.695	0.001	15.578	0.013

The degree of equivalence of laboratory  $i$  with respect to the key comparison reference value is given by a pair of terms terms, both expressed in dB:  $D_i = (x_i - x_R)$  and its expanded uncertainty  $U_i$  ( $k = 2$ ). The equations for the computation of  $U_i$  are given in page 112 of the Final Report.

The degree of equivalence between two laboratories  $i$  and  $j$  is given by a pair of terms, both expressed in dB :

$D_{ij} = (D_i - D_j)$  and its expanded uncertainty  $U_{ij}$  ( $k = 2$ ) with  $U_{ij} = 2(u_i^2 + u_j^2)^{1/2}$ .

Note that the terms  $D_i$  and  $D_{ij}$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB1

REFERENCE PLANE : PC-7 / R140

FREQUENCY : 12.4 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.001	0.055
NPL	0.003	0.031
PTB	0.007	0.021
NIST	-0.011	0.027
VNIIFTRI	0.086	0.072

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		-0.002	0.088	-0.007	0.082	0.012	0.085	-0.085	0.106
0.002	0.088			-0.004	0.050	0.014	0.055	-0.083	0.083
0.007	0.082	0.004	0.050			0.018	0.045	-0.079	0.077
-0.012	0.085	-0.014	0.055	-0.018	0.045			-0.097	0.080
0.085	0.106	0.083	0.083	0.079	0.077	0.097	0.080		

FREQUENCY : 13.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.001	0.065
NPL	-0.012	0.044
PTB	0.004	0.033
NIST	-0.033	0.037
VNIIFTRI	0.040	0.050

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.013	0.092	-0.002	0.084	0.034	0.086	-0.039	0.096
-0.013	0.092			-0.016	0.057	0.021	0.060	-0.052	0.074
0.002	0.084	0.016	0.057			0.037	0.047	-0.037	0.064
-0.034	0.086	-0.021	0.060	-0.037	0.047			-0.073	0.067
0.039	0.096	0.052	0.074	0.037	0.064	0.073	0.067		

FREQUENCY : 15 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	-0.004	0.063
NPL	0.017	0.033
PTB	-0.005	0.029
NIST	-0.014	0.030
VNIIFTRI	0.008	0.052

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		-0.021	0.090	0.001	0.088	0.010	0.088	-0.012	0.104
0.021	0.090			0.022	0.053	0.031	0.054	0.009	0.077
-0.001	0.088	-0.022	0.053			0.009	0.050	-0.013	0.075
-0.010	0.088	-0.031	0.054	-0.009	0.050			-0.022	0.075
0.012	0.104	-0.009	0.077	0.013	0.075	0.022	0.075		

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB1

REFERENCE PLANE : PC-7 / R140

FREQUENCY : 17.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	-0.003	0.046
NPL	-0.028	0.062
PTB	0.001	0.022
NIST	0.002	0.022
VNIIFTRI	0.204	0.052

LNE	NPL	PTB	NIST	VNIIFTRI
$D_{ij}$ / dB	$U_{ij}$ / dB	$D_{ij}$ / dB	$U_{ij}$ / dB	$D_{ij}$ / dB
	0.025	0.101	-0.003	0.088
-0.025	0.101		-0.028	0.072
0.003	0.088	0.028	0.072	
0.005	0.088	0.030	0.073	
0.207	0.095	0.232	0.081	
		0.204	0.064	0.202
			0.064	

FREQUENCY : 18 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.004	0.061
NPL	0.030	0.039
PTB	-0.032	0.039
NIST	-0.003	0.038


LNE	NPL	PTB	NIST
$D_{ij}$ / dB	$U_{ij}$ / dB	$D_{ij}$ / dB	$U_{ij}$ / dB
	-0.026	0.089	0.036
0.026	0.089		0.062
-0.036	0.089	-0.062	0.059
-0.007	0.088	-0.033	0.058
		0.029	0.058

**CCEM.RF-K9**

**Excess noise ratio, 12.4 GHz**


**Source : TSB1, Reference plane : PC-7 / R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**      Excess noise ratio, 13.5 GHz  
Source : TSB1, Reference plane : PC-7 / R140  
Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**      Excess noise ratio, 15 GHz  
Source : TSB1, Reference plane : PC-7 / R140  
Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 17.5 GHz**

**Source : TSB1, Reference plane : PC-7 / R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 18 GHz**

**Source : TSB1, Reference plane : PC-7 / R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

**MEASURAND : Excess noise ratio**

**NOISE SOURCE : TSB1**

**REFERENCE PLANE : PC-7**

$x_i$  : averaged Excess noise ratio measured by laboratory  $i$

$u_i$  : averaged standard uncertainty of  $x_i$

Lab $i$	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	Date of measurement
	Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz		
LNE	15.877	0.044	15.929	0.043	15.956	0.045	15.836	0.045	15.741	0.045	Sep 97, Jan 99, Dec 00
NPL	15.856	0.049	15.896	0.037	15.957	0.034	15.809	0.045	15.766	0.040	May 98
PTB	15.871	0.014	15.928	0.016	15.961	0.018	15.847	0.019	15.689	0.021	Jun 97, Apr 99
NIST	15.842	0.023	15.881	0.024	15.950	0.024	15.833	0.025	15.717	0.025	Apr 00
VNIIFTRI	15.954	0.035	15.970	0.028	15.982	0.033	16.055	0.027	-	-	Sep - Oct 00

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB1

REFERENCE PLANE : PC-7

At each frequency, the key comparison reference value,  $x_R$ , is calculated as the unweighted mean of the participants results with exclusion of outliers. Its standard uncertainty  $u_R$  is computed as given in page 112 of the Final Report.

Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz	
$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB
15.862	0.008	15.921	0.015	15.956	0.002	15.831	0.008	15.728	0.016

The degree of equivalence of laboratory  $i$  with respect to the key comparison reference value is given by a pair of terms terms, both expressed in dB:  $D_i = (x_i - x_R)$  and its expanded uncertainty  $U_i$  ( $k = 2$ ). The equations for the computation of  $U_i$  are given in page 112 of the Final Report.

The degree of equivalence between two laboratories  $i$  and  $j$  is given by a pair of terms, both expressed in dB :

$D_{ij} = (D_i - D_j)$  and its expanded uncertainty  $U_{ij}$  ( $k = 2$ ) with  $U_{ij} = 2(u_i^2 + u_j^2)^{1/2}$ .

Note that the terms  $D_i$  and  $D_{ij}$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB1

REFERENCE PLANE : PC-7

FREQUENCY : 12.4 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.016	0.064
NPL	-0.005	0.071
PTB	0.010	0.025
NIST	-0.019	0.036
VNIIFTRI	0.093	0.072

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.021	0.131	0.006	0.092	0.035	0.099	-0.077	0.112
-0.021	0.131			-0.015	0.102	0.014	0.108	-0.098	0.120
-0.006	0.092	0.015	0.102			0.029	0.054	-0.083	0.075
-0.035	0.099	-0.014	0.108	-0.029	0.054			-0.112	0.084
0.077	0.112	0.098	0.120	0.083	0.075	0.112	0.084		

FREQUENCY : 13.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.008	0.073
NPL	-0.025	0.065
PTB	0.007	0.039
NIST	-0.040	0.048
VNIIFTRI	0.049	0.053

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.033	0.113	0.001	0.091	0.048	0.098	-0.041	0.103
-0.033	0.113			-0.032	0.080	0.015	0.088	-0.074	0.093
-0.001	0.091	0.032	0.080			0.047	0.057	-0.042	0.064
-0.048	0.098	-0.015	0.088	-0.047	0.057			-0.089	0.074
0.041	0.103	0.074	0.093	0.042	0.064	0.089	0.074		

FREQUENCY : 15 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.000	0.063
NPL	0.001	0.048
PTB	0.005	0.025
NIST	-0.006	0.034
VNIIFTRI	0.026	0.066

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		-0.001	0.112	-0.004	0.096	0.006	0.101	-0.026	0.111
0.001	0.112			-0.003	0.076	0.007	0.083	-0.025	0.095
0.004	0.096	0.003	0.076			0.011	0.059	-0.021	0.075
-0.006	0.101	-0.007	0.083	-0.011	0.059			-0.032	0.082
0.026	0.111	0.025	0.095	0.021	0.075	0.032	0.082		

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB1

REFERENCE PLANE : PC-7

FREQUENCY : 17.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.005	0.066
NPL	-0.022	0.066
PTB	0.015	0.031
NIST	0.002	0.039
VNIIFTRI	0.224	0.056

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.027	0.127	-0.011	0.097	0.003	0.103	-0.219	0.105
-0.027	0.127			-0.037	0.097	-0.024	0.103	-0.246	0.105
0.011	0.097	0.037	0.097			0.013	0.062	-0.209	0.065
-0.003	0.103	0.024	0.103	-0.013	0.062			-0.222	0.074
0.219	0.105	0.246	0.105	0.209	0.065	0.222	0.074		

FREQUENCY : 18 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.013	0.071
NPL	0.038	0.065
PTB	-0.039	0.044
NIST	-0.011	0.048


LNE		NPL		PTB		NIST	
$D_{ij}$ / dB	$U_{ij}$ / dB						
		-0.025	0.120	0.052	0.099	0.024	0.102
0.025	0.120			0.077	0.090	0.049	0.094
-0.052	0.099	-0.077	0.090			-0.028	0.065
-0.024	0.102	-0.049	0.094	0.028	0.065		

**CCEM.RF-K9**

**Excess noise ratio, 12.4 GHz**

**Source : TSB1, Reference plane : PC-7**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 13.5 GHz**


**Source : TSB1, Reference plane : PC-7**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**      Excess noise ratio, 15 GHz  
Source : TSB1, Reference plane : PC-7  
Degrees of equivalence,  $D_i$  and expanded uncertainty  $U_i$  ( $k = 2$ )




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 17.5 GHz**

**Source : TSB1, Reference plane : PC-7**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$ , ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 18 GHz**

**Source : TSB1, Reference plane : PC-7**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

**MEASURAND : Excess noise ratio**

**NOISE SOURCE : TSA2**

**REFERENCE PLANE : R140**

$x_i$  : averaged Excess noise ratio measured by laboratory  $i$

$u_i$  : averaged standard uncertainty of  $x_i$

Lab $i$	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	Date of measurement
	Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz		
LNE	15.761	0.038	15.803	0.038	15.761	0.040	15.770	0.039	15.761	0.039	Sep 97, Jan 99, Dec 00
NPL	15.758	0.022	15.755	0.024	15.766	0.022	15.766	0.031	15.770	0.031	Apr 97, Mar - Apr 99
PTB	15.780	0.012	15.793	0.015	15.776	0.016	15.761	0.017	15.730	0.020	Feb 98
NIST	15.758	0.018	15.756	0.018	15.751	0.018	15.753	0.020	15.749	0.020	Apr 00
VNIIFTRI	15.888	0.030	15.816	0.026	15.795	0.028	15.922	0.024	-	-	Sep - Oct 00

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSA2

REFERENCE PLANE : R140

At each frequency, the key comparison reference value,  $x_R$ , is calculated as the unweighted mean of the participants results with exclusion of outliers. Its standard uncertainty  $u_R$  is computed as given in page 112 of the Final Report.

Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz	
$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB
15.759	0.001	15.785	0.012	15.770	0.007	15.762	0.004	15.753	0.009

The degree of equivalence of laboratory  $i$  with respect to the key comparison reference value is given by a pair of terms terms, both expressed in dB:  $D_i = (x_i - x_R)$  and its expanded uncertainty  $U_i$  ( $k = 2$ ). The equations for the computation of  $U_i$  are given in page 112 of the Final Report.

The degree of equivalence between two laboratories  $i$  and  $j$  is given by a pair of terms, both expressed in dB :

$D_{ij} = (D_i - D_j)$  and its expanded uncertainty  $U_{ij}$  ( $k = 2$ ) with  $U_{ij} = 2(u_i^2 + u_j^2)^{1/2}$ .

Note that the terms  $D_i$  and  $D_{ij}$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSA2

REFERENCE PLANE : R140

FREQUENCY : 12.4 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.002	0.044
NPL	-0.001	0.025
PTB	0.021	0.024
NIST	-0.001	0.021
VNIIFTRI	0.129	0.060

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.003	0.088	-0.019	0.080	0.003	0.084	-0.127	0.097
-0.003	0.088			-0.022	0.050	0.000	0.057	-0.131	0.074
0.019	0.080	0.022	0.050			0.022	0.043	-0.108	0.065
-0.003	0.084	0.000	0.057	-0.022	0.043			-0.130	0.070
0.127	0.097	0.131	0.074	0.108	0.065	0.130	0.070		

FREQUENCY : 13.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.018	0.063
NPL	-0.030	0.044
PTB	0.008	0.034
NIST	-0.029	0.037
VNIIFTRI	0.031	0.047

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.048	0.089	0.010	0.081	0.047	0.083	-0.013	0.092
-0.048	0.089			-0.038	0.056	-0.001	0.059	-0.061	0.070
-0.010	0.081	0.038	0.056			0.037	0.047	-0.023	0.060
-0.047	0.083	0.001	0.059	-0.037	0.047			-0.060	0.063
0.013	0.092	0.061	0.070	0.023	0.060	0.060	0.063		

FREQUENCY : 15 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	-0.009	0.063
NPL	-0.004	0.037
PTB	0.006	0.029
NIST	-0.019	0.032
VNIIFTRI	0.025	0.046

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		-0.004	0.090	-0.015	0.086	0.010	0.087	-0.034	0.097
0.004	0.090			-0.011	0.054	0.015	0.056	-0.030	0.071
0.015	0.086	0.011	0.054			0.025	0.048	-0.019	0.064
-0.010	0.087	-0.015	0.056	-0.025	0.048			-0.044	0.067
0.034	0.097	0.030	0.071	0.019	0.064	0.044	0.067		

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSA2

REFERENCE PLANE : R140

FREQUENCY : 17.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.007	0.056
NPL	0.004	0.044
PTB	-0.001	0.025
NIST	-0.009	0.029
VNIIFTRI	0.160	0.049

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.004	0.100	0.009	0.085	0.017	0.088	-0.152	0.092
-0.004	0.100			0.005	0.071	0.013	0.074	-0.156	0.078
-0.009	0.085	-0.005	0.071			0.008	0.052	-0.161	0.059
-0.017	0.088	-0.013	0.074	-0.008	0.052			-0.169	0.062
0.152	0.092	0.156	0.078	0.161	0.059	0.169	0.062		

FREQUENCY : 18 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.009	0.058
NPL	0.018	0.047
PTB	-0.022	0.033
NIST	-0.003	0.033


LNE		NPL		PTB		NIST	
$D_{ij}$ / dB	$U_{ij}$ / dB						
		-0.009	0.100	0.031	0.088	0.012	0.088
0.009	0.100			0.040	0.074	0.021	0.074
-0.031	0.088	-0.040	0.074			-0.019	0.057
-0.012	0.088	-0.021	0.074	0.019	0.057		

**CCEM.RF-K9**

**Excess noise ratio, 12.4 GHz**


**Source : TSA2, Reference plane : R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**      Excess noise ratio, 13.5 GHz  
Source : TSA2, Reference plane : R140  
Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$ , ( $k = 2$ )



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**      Excess noise ratio, 15 GHz  
Source : TSA2, Reference plane : R140  
Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 17.5 GHz**

**Source : TSA2, Reference plane : R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 18 GHz**

**Source : TSA2, Reference plane : R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

**MEASURAND : Excess noise ratio**

**NOISE SOURCE : TSB2**

**REFERENCE PLANE : PC-7 / R140**

$x_i$  : averaged Excess noise ratio measured by laboratory  $i$

$u_i$  : averaged standard uncertainty of  $x_i$

Lab $i$	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	Date of measurement
	Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz		
LNE	4.843	0.043	4.779	0.042	4.717	0.044	4.876	0.043	4.873	0.043	Sep 97, Jan 99, Dec 00
NPL	4.852	0.023	4.751	0.024	4.710	0.023	4.880	0.032	4.877	0.033	Apr 97, Mar - Apr 99
PTB	4.844	0.020	4.768	0.015	4.720	0.018	4.883	0.020	4.751	0.040	Feb 98
NIST	4.841	0.018	4.731	0.018	4.665	0.018	4.836	0.019	4.831	0.021	Apr 00
VNIIFTRI	4.885	0.032	4.754	0.027	4.681	0.027	4.845	0.031	-	-	Sep - Oct 00

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB2

REFERENCE PLANE : PC-7 / R140

At each frequency, the key comparison reference value,  $x_R$ , is calculated as the unweighted mean of the participants results with exclusion of outliers. Its standard uncertainty  $u_R$  is computed as given in page 112 of the Final Report.

Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz	
$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB
4.845	0.002	4.757	0.008	4.707	0.009	4.880	0.002	4.860	0.015

The degree of equivalence of laboratory  $i$  with respect to the key comparison reference value is given by a pair of terms terms, both expressed in dB:  $D_i = (x_i - x_R)$  and its expanded uncertainty  $U_i$  ( $k = 2$ ). The equations for the computation of  $U_i$  are given in page 112 of the Final Report.

The degree of equivalence between two laboratories  $i$  and  $j$  is given by a pair of terms, both expressed in dB :

$D_{ij} = (D_i - D_j)$  and its expanded uncertainty  $U_{ij}$  ( $k = 2$ ) with  $U_{ij} = 2(u_i^2 + u_j^2)^{1/2}$ .

Note that the terms  $D_i$  and  $D_{ij}$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB2

REFERENCE PLANE : PC-7 / R140

FREQUENCY : 12.4 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	-0.002	0.061
NPL	0.007	0.032
PTB	-0.001	0.029
NIST	-0.004	0.026
VNIIFTRI	0.040	0.064

	LNE		NPL		PTB		NIST		VNIIFTRI	
	$D_{ij}$ / dB	$U_{ij}$ / dB								
			-0.008	0.096	-0.001	0.094	0.002	0.093	-0.042	0.107
	0.008	0.096			0.007	0.060	0.010	0.058	-0.034	0.078
	0.001	0.094	-0.007	0.060			0.003	0.054	-0.041	0.075
	-0.002	0.093	-0.010	0.058	-0.003	0.054			-0.044	0.073
	0.042	0.107	0.034	0.078	0.041	0.075	0.044	0.073		

FREQUENCY : 13.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.023	0.068
NPL	-0.006	0.041
PTB	0.011	0.028
NIST	-0.026	0.032
VNIIFTRI	-0.003	0.045

	LNE		NPL		PTB		NIST		VNIIFTRI	
	$D_{ij}$ / dB	$U_{ij}$ / dB								
			0.029	0.097	0.011	0.090	0.048	0.092	0.025	0.100
	-0.029	0.097			-0.018	0.057	0.019	0.060	-0.003	0.072
	-0.011	0.090	0.018	0.057			0.037	0.047	0.014	0.062
	-0.048	0.092	-0.019	0.060	-0.037	0.047			-0.023	0.065
	-0.025	0.100	0.003	0.072	-0.014	0.062	0.023	0.065		

FREQUENCY : 15 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.010	0.064
NPL	0.003	0.036
PTB	0.013	0.031
NIST	-0.042	0.040
VNIIFTRI	-0.026	0.042

	LNE		NPL		PTB		NIST		VNIIFTRI	
	$D_{ij}$ / dB	$U_{ij}$ / dB								
			0.007	0.098	-0.003	0.094	0.052	0.094	0.036	0.103
	-0.007	0.098			-0.010	0.058	0.045	0.058	0.029	0.070
	0.003	0.094	0.010	0.058			0.055	0.051	0.039	0.065
	-0.052	0.094	-0.045	0.058	-0.055	0.051			-0.016	0.065
	-0.036	0.103	-0.029	0.070	-0.039	0.065	0.016	0.065		

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB2

REFERENCE PLANE : PC-7 / R140

FREQUENCY : 17.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	-0.003	0.050
NPL	0.000	0.037
PTB	0.003	0.023
NIST	-0.043	0.038
VNIIFTRI	-0.035	0.062

LNE	NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$D_{ij}$ / dB	$U_{ij}$ / dB						
			-0.003	0.107	-0.007	0.095	0.040	0.094
0.003	0.107				-0.003	0.075	0.043	0.074
0.007	0.095	0.003	0.075			0.047	0.055	0.035
-0.040	0.094	-0.043	0.074	-0.047	0.055			-0.009
-0.031	0.106	-0.035	0.089	-0.038	0.074	0.009	0.073	

FREQUENCY : 18 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.013	0.058
NPL	0.016	0.048
PTB	-0.109	0.085
NIST	-0.029	0.038


LNE	NPL		PTB		NIST	
$D_{ij}$ / dB	$D_{ij}$ / dB	$U_{ij}$ / dB	$D_{ij}$ / dB	$U_{ij}$ / dB	$D_{ij}$ / dB	$U_{ij}$ / dB
			-0.003	0.108	0.122	0.117
0.003	0.108				0.126	0.103
-0.122	0.117	-0.126	0.103			-0.080
-0.042	0.096	-0.045	0.077	0.080	0.090	

**CCEM.RF-K9**

**Excess noise ratio, 12.4 GHz**

**Source : TSB2, Reference plane : PC-7 / R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 13.5 GHz**


**Source : TSB2, Reference plane : PC-7 / R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**      Excess noise ratio, 15 GHz  
Source : TSB2, Reference plane : PC-7 / R140  
Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 17.5 GHz**

**Source : TSB2, Reference plane : PC-7 / R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 18 GHz**

**Source : TSB2, Reference plane : PC-7 / R140**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

**MEASURAND : Excess noise ratio**

**NOISE SOURCE : TSB2**

**REFERENCE PLANE : PC-7**

$x_i$  : averaged Excess noise ratio measured by laboratory  $i$

$u_i$  : averaged standard uncertainty of  $x_i$

Lab $i$	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	$x_i$ / dB	$u_i$ / dB	Date of measurement
	Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz		
LNE	4.949	0.046	4.893	0.046	4.849	0.048	5.040	0.047	5.044	0.047	Sep 97, Jan 99, Dec 00
NPL	4.956	0.052	4.858	0.039	4.831	0.035	5.005	0.045	5.006	0.047	Apr 97, Mar - Apr 99
PTB	4.952	0.021	4.870	0.017	4.839	0.019	5.031	0.021	4.923	0.041	Feb 98
NIST	4.943	0.023	4.836	0.023	4.791	0.029	5.000	0.029	4.995	0.030	Apr 00
VNIIFTRI	4.996	0.032	4.883	0.027	4.866	0.028	5.056	0.041	-	-	Sep - Oct 00

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB2

REFERENCE PLANE : PC-7

At each frequency, the key comparison reference value,  $x_R$ , is calculated as the unweighted mean of the participants results with exclusion of outliers. Its standard uncertainty  $u_R$  is computed as given in page 112 of the Final Report.

Frequency 12.4 GHz		Frequency 13.5 GHz		Frequency 15 GHz		Frequency 17.5 GHz		Frequency 18 GHz	
$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB	$x_R$ / dB	$u_R$ / dB
4.950	0.003	4.868	0.010	4.846	0.008	5.026	0.011	4.992	0.025

The degree of equivalence of laboratory  $i$  with respect to the key comparison reference value is given by a pair of terms terms, both expressed in dB:  $D_i = (x_i - x_R)$  and its expanded uncertainty  $U_i$  ( $k = 2$ ). The equations for the computation of  $U_i$  are given in page 112 of the Final Report.

The degree of equivalence between two laboratories  $i$  and  $j$  is given by a pair of terms, both expressed in dB :

$D_{ij} = (D_i - D_j)$  and its expanded uncertainty  $U_{ij}$  ( $k = 2$ ) with  $U_{ij} = 2(u_i^2 + u_j^2)^{1/2}$ .

Note that the terms  $D_i$  and  $D_{ij}$  are computed with the opposite sign in the Final Report.

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB2

REFERENCE PLANE : PC-7

FREQUENCY : 12.4 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	-0.001	0.065
NPL	0.006	0.073
PTB	0.002	0.030
NIST	-0.007	0.033
VNIIFTRI	0.046	0.064

	LNE		NPL		PTB		NIST		VNIIFTRI	
	$D_{ij}$ / dB	$U_{ij}$ / dB								
			-0.007	0.138	-0.003	0.101	0.006	0.102	-0.047	0.112
	0.007	0.138			0.004	0.111	0.013	0.113	-0.040	0.121
	0.003	0.101	-0.004	0.111			0.009	0.062	-0.044	0.077
	-0.006	0.102	-0.013	0.113	-0.009	0.062			-0.053	0.079
	0.047	0.112	0.040	0.121	0.044	0.077	0.053	0.079		

FREQUENCY : 13.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.025	0.073
NPL	-0.010	0.064
PTB	0.002	0.033
NIST	-0.032	0.041
VNIIFTRI	0.015	0.046

	LNE		NPL		PTB		NIST		VNIIFTRI	
	$D_{ij}$ / dB	$U_{ij}$ / dB								
			0.035	0.120	0.023	0.097	0.057	0.102	0.010	0.106
	-0.035	0.120			-0.012	0.085	0.022	0.091	-0.025	0.095
	-0.023	0.097	0.012	0.085			0.034	0.057	-0.013	0.064
	-0.057	0.102	-0.022	0.091	-0.034	0.057			-0.047	0.071
	-0.010	0.106	0.025	0.095	0.013	0.064	0.047	0.071		

FREQUENCY : 15 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.003	0.070
NPL	-0.016	0.052
PTB	-0.007	0.031
NIST	-0.055	0.060
VNIIFTRI	0.020	0.042

	LNE		NPL		PTB		NIST		VNIIFTRI	
	$D_{ij}$ / dB	$U_{ij}$ / dB								
			0.018	0.119	0.010	0.103	0.058	0.112	-0.017	0.111
	-0.018	0.119			-0.009	0.080	0.039	0.091	-0.035	0.090
	-0.010	0.103	0.009	0.080			0.048	0.069	-0.027	0.068
	-0.058	0.112	-0.039	0.091	-0.048	0.069			-0.075	0.081
	0.017	0.111	0.035	0.090	0.027	0.068	0.075	0.081		

## Key comparison CCEM.RF-K9

MEASURAND : Excess noise ratio

NOISE SOURCE : TSB2

REFERENCE PLANE : PC-7

FREQUENCY : 17.5 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.014	0.076
NPL	-0.022	0.073
PTB	0.005	0.039
NIST	-0.026	0.050
VNIIFTRI	0.030	0.067

LNE		NPL		PTB		NIST		VNIIFTRI	
$D_{ij}$ / dB	$U_{ij}$ / dB								
		0.036	0.131	0.009	0.104	0.040	0.111	-0.016	0.125
-0.036	0.131			-0.026	0.099	0.005	0.107	-0.051	0.122
-0.009	0.104	0.026	0.099			0.031	0.072	-0.025	0.092
-0.040	0.111	-0.005	0.107	-0.031	0.072			-0.056	0.100
0.016	0.125	0.051	0.122	0.025	0.092	0.056	0.100		

FREQUENCY : 18 GHz

Lab *j* →

Lab *i*

	$D_i$ / dB	$U_i$ / dB
LNE	0.052	0.084
NPL	0.014	0.084
PTB	-0.069	0.077
NIST	0.003	0.066


LNE		NPL		PTB		NIST	
$D_{ij}$ / dB	$U_{ij}$ / dB						
		0.038	0.133	0.121	0.125	0.049	0.112
-0.038	0.133			0.083	0.125	0.011	0.112
-0.121	0.125	-0.083	0.125			-0.072	0.102
-0.049	0.112	-0.011	0.112	0.072	0.102		

**CCEM.RF-K9**

**Excess noise ratio, 12.4 GHz**

**Source : TSB2, Reference plane : PC-7**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 13.5 GHz**


**Source : TSB2, Reference plane : PC-7**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**      Excess noise ratio, 15 GHz  
**Source : TSB2, Reference plane : PC-7**  
**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 17.5 GHz**

**Source : TSB2, Reference plane : PC-7**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**




Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.

**CCEM.RF-K9**

**Excess noise ratio, 18 GHz**

**Source : TSB2, Reference plane : PC-7**

**Degrees of equivalence,  $D_i$ , and expanded uncertainty  $U_i$  ( $k = 2$ )**



Note that the terms  $D_i$  are computed with the opposite sign in the Final Report.