

Results of differential calibration of geodetic-type receivers at the SG

Last updated 11 May 2010

1. General description of the calibration

This report concerns the calibration of the hardware delays incurred by time signals for different geodetic-type GPS systems operated at the SG in Singapore.

The systems (receiver+antenna) are designated by a 4-letter acronym.

The link between acronym and actual hardware references may be found [here](#).

The results presented in Section 3 should be used for time transfer with other equipment calibrated using the same procedure. The standard uncertainty on such a link calibration is taken to be 5 ns (1 σ).

2. Calibration procedure

The calibration is a differential calibration with respect to a travelling receiver which is either a reference receiver from the BIPM or a receiver calibrated vs. a BIPM reference receiver. The BIPM reference receiver is presently BP0C, an Ashtech Z12-T (see [TM172](#) for information on the BIPM travelling receivers and [TM116](#) for the original calibration of the reference receiver).

The calibration operational procedure is available [here](#). Note that different versions of the document were used, depending on the epoch of calibration; see the annex “Revision history” in the most recent version.

3. Calibration results

Results are presented in a computation sheet which is available through the link in the column “Results P1-P2/ns”. Explanatory information on the computation sheet is available [here](#).

System	Period	Calib. dates	Reference	Results P1-P2/ns	Operations report
SG2P	2010/03	55274-55285	BP0U	224.6 – 222.3	Report2010_SG.pdf
SG02	2010/03	55274-55285	BP0U	222.3 – 217.5	Report2010_SG.pdf